

Minimum Initial Dilution Re-Evaluation Analysis of the San Elijo Ocean Outfall

4 November 2022

Submitted to:

Chris Trees
Director of Operations
San Elijo Joint Powers Authority



Submitted by:

Scott Jenkins, Ph.D.
Makrom Shatila, P.E.

Michael Baker
I N T E R N A T I O N A L

ABSTRACT:

This is a Minimum Initial Dilution Re-Evaluation Study to determine whether the proposed addition of brine from the City of Escondido membrane filtration reverse osmosis (MFRO) facility (currently under construction) could change the San Elijo Ocean Outfall (SEOO) discharge characteristics sufficiently to affect the 237:1 initial dilution (parts seawater per parts effluent) that is currently assigned within National Pollutant Discharge Elimination System (NPDES) Permit Order Nos. R9-2018-0002 and R9-2018-0003, as originally mandated in Order No. R9-2005-0100. The study evaluates four (4) initial dilution scenarios that were posed to address the San Diego Regional Water Quality Control Board (RWQCB) requirements for the Initial Dilution Study and assess initial dilution for a potential range of future seasonal SEOO operating conditions. These scenarios are evaluated using two independent dilution models approved by the California State Water Resources Control Board (SWRCB), namely:

- Plumes 20 (UM3) and
- CORMIX v-12.

Order Nos. R9-2018-0002 and R9-2018-0003 assign an initial dilution of 237:1 to the SEOO discharge on the basis of initial dilution modeling performed by the RWQCB and SWRCB in 2005 using historic ocean density profiles from June 2003-December 2003, a maximum SEOO discharge flow of 23.25 mgd and an effluent salinity of 1.2 psu. Maximum anticipated future brine discharges to the SEOO are projected to result in only a slight increase in salinity to approximately 1.34 psu. By itself, such a small increase in salinity would have no discernible effect on SEOO initial dilution. Changes in SEOO discharge flows, on the other hand, may offer the potential for discernible effects on SEOO initial dilution. To evaluate this question, this study assesses a range of potential discharge flow and salinity scenarios, and the effect on SEOO initial dilution through a range of four seasonal oceanographic conditions, using observed seasonal SEOO ocean density (temperature/salinity) data collected during 2013-2014 by MTS, as approved by the RWQCB. Model Scenarios #1 and #2 assess initial dilutions associated with maximum flow/maximum brine conditions during winter and spring conditions, while Scenarios #3 and #4 assess minimum flow/maximum brine conditions during summer and fall conditions.

Table of Contents

1) Introduction.....	1
2) Formulation of Dilution Scenarios.....	3
3) Dilution Model Parameter Assignments and Dilution Output	6
4) Plumes 20 Initial Dilution Results for Discharge Scenario #1: Maximum Discharge With Maximum Brine Additions for Winter Density Profiles.....	8
5) Plumes 20 Initial Dilution Results for Discharge Scenario #2: Maximum Discharge With Maximum Brine Additions for Spring Density Profiles.....	10
6) Plumes 20 Initial Dilution Results for Discharge Scenario #3: Minimum Discharge With Maximum Brine Additions for Summer Density Profiles	12
7) Plumes 20 Initial Dilution Results for Discharge Scenario #4: Minimum Discharge With Maximum Brine Additions for Autumn Density Profiles	14
8) Conclusions.....	16
9) References:.....	18

List of Appendices

APPENDIX A: Temperature-Salinity-Density Profiles Used in the Updated SEOO Minimum Initial Dilution Study based on Monthly Water Column Monitoring from November 2013 Through October 2014

APPENDIX B: Plumes 20 Initial Dilution Results for Discharge Scenario #1: Maximum Discharge Rate (23.25 mgd) with Maximum Brine Additions based on Winter Density Profiles from December 2013 Through February 2014

APPENDIX C: Plumes 20 Initial Dilution Results for Discharge Scenario #2: Maximum Discharge Rate (23.25 mgd) with Maximum Brine Additions based on Spring Density Profiles from March 2014 Through May 2014

APPENDIX D: Plumes 20 Initial Dilution Results for Discharge Scenario #3: Minimum Discharge Rate (7.2 mgd) with Maximum Brine Additions based on Summer Density Profiles from June 2014 Through August 2014

APPENDIX E: Plumes 20 Initial Dilution Results for Discharge Scenario #4: Minimum Discharge Rate (7.2 mgd) with Maximum Brine Additions based on Autumn Density Profiles from September 2014 Through November 2014

List of Tables

Table 1: Initial Dilution Model Scenarios SEOO Initial Dilution Study	4
Table 2: Projected Discharge Flows and Salinities Maximum and Minimum SEOO Discharge Flows	5
Table 3: Summary of Initial Dilution Simulations.....	17

List of Figures

Figure 4.1: Plumes 20 and CORMIX v-12 initial dilution solutions for Scenario #1 based on maximum allowable SEOO discharge of 23.25 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility applied to the monthly water column density profiles in Appendix A under winter conditions from December 2013 through February 2014. The CORMIX v-12 solution for February 2014 oceanographic conditions is shown above, as the nearly homogeneous nature of ocean density throughout the depth profile that existed during February 2014 caused the Plumes 20 simulation to truncate prior to converging on an appropriate initial dilution solution.....	9
Figure 5.1: Plumes 20 initial dilution solutions for Scenario #2 based on maximum allowable SEOO discharge of 23.25 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility applied to the monthly water column density profiles in Appendix A under spring conditions from March 2014 through May 2014.....	11
Figure 6.1: Plumes 20 initial dilution solutions for Scenario #3 based on historic minimum SEOO discharge of 7.2 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility, resulting in a discharge salinity of 1.88 psu. These discharge inputs are applied to the monthly water column density profiles in Appendix A under summer conditions from June 2014 through August 2014.....	13
Figure 7.1: Plumes 20 initial dilution solutions for Scenario #4 based on historic minimum SEOO discharge of 7.2 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility applied to the monthly water column density profiles in Appendix A under autumn conditions from September 2014 through November 2014.....	15

1) Introduction

The National Pollutant Discharge Elimination System (NPDES) permits regulate wastewater discharges from the San Elijo Ocean Outfall (SEOO) into the Pacific Ocean. The Regional Water Quality Control Board (RWQCB), San Diego Region presently issues four (4) separate orders under the SEOO NPDES permit No. CA0107999, including:

- Order No. R9-2018-0002 regulates the City of Escondido discharge to the SEOO from the Hale Avenue Resource Recovery Facility (HARRF) and the proposed City of Escondido Membrane Filtration/Reverse Osmosis (MFRO) facility.
- Order No. R9-2018-0003 regulates the San Elijo Joint Powers Authority (SEJPA) discharge to the SEOO from the San Elijo Water Campus (SEWC), which includes secondary treated wastewater from the SEWC and reverse osmosis brine from the SEWC advanced water treatment facility.
- Order No. R9-2014-0094 (as amended) regulates the discharge of 0.07 mgd of reverse osmosis brine from the Stone Brewing Company to the SEOO.
- Order No. R9-2012-0015 (as amended) regulates the discharge of cooling tower blowdown brine to the SEOO from the Palomar Energy Center (PEC).

The proposed 2.0 mgd MFRO facility would generate approximately 0.5 mgd of brine that contains an estimated total dissolved solids concentration of 4500 mg/L (roughly 4.5 psu). Except for downtime for facility maintenance, the MFRO will operate on a year-round basis, including periods of wet weather. Order Nos. R9-2018-0002 and R9-2018-0003 require the City of Escondido and SEJPA to conduct a *Minimum Initial Dilution Re-Evaluation Study* to determine whether the proposed addition of brine from the City of Escondido MFRO facility (currently under construction) could change the SEOO discharge characteristics sufficiently to affect the 237:1 initial dilution (parts sea water per parts effluent) that is currently assigned within Order Nos. R9-2018-0002 and R9-2018-0003, as originally mandated in Order No. R9-2005-0100. This 237:1 assigned initial dilution was computed in 2005 by the State Water Resources Control Board (SWRCB) using the U.S. Environmental Protection Agency (EPA) Visual Plumes (UM3) model and the following input:

- a maximum permitted SEOO discharge flow of 23.25 million gallons per day (mgd),
- a combined SEOO discharge salinity concentration of 1.2 practical salinity units (psu),
- a combined SEOO discharge temperature of 22.5 degrees Centigrade, and
- ambient ocean density (temperature/salinity) data from February 2004 (deemed to represent average monthly conditions during the minimum month of the year).

Since the original 2005 minimum initial dilution analysis for the SEOO, the Visual Plumes (UM3) dilution model has undergone a series of upgrades, (cf. Frick, et al., 2010, & 2016), and the most recent upgrade

is now referred to as Plumes 20 (UM3). Since 2018, the SWRCB has favored the use of the Plumes 20 (UM3) model for dilution problems involving brine additions, as detailed in their 2018 guidance document. The SWRCB provides this guidance document and Plumes 20 (UM3) executable source code at its website:

https://www.waterboards.ca.gov/water_issues/programs/ocean/

However, Visual Plumes and Plumes 20 are not the only dilution models approved for use by the SWRCB for minimum initial dilution analyses. The expert system model CORMIX is approved by U.S. EPA in its beta testing of generation 2 & 3 dilution models, (cf. Baumgartner, et al. 1994, Frick et al., 2003), and has been used to establish the minimum initial dilution in NPDES permits for the Hyperion 1-Mile and 5-Mile Ocean Outfalls, (NPDES No. CA-0109991, Order No. R4-2017-0045), cf. RWQCB (2017), Walker (2016 & 2020). Since 2003, CORMIX has gone through a succession of 12 upgrades, and the latest version is CORMIX v-12, which is supported by and available from MixZon, Inc, cf. Doneker and Jirka, (1999 & 2022) In the following minimum initial dilution re-evaluation of the San Elijo Ocean Outfall (SEOO), the Plumes 20 (UM3) model was used as the primary analysis tool with cross-checks of suspected spurious results performed using CORMIX v-12.

2) Formulation of Dilution Scenarios

During periods of wet weather, SEOO flows may approach the maximum permitted flow of 23.25 mgd, but the MFRO brine discharge (along with brine discharges from the SEWC, PEC and Stone Brewing Company) will comprise a small percent of the total discharged flow. During summer periods of peak recycled water demand, SEOO discharge flows will be considerably lower as a significant majority of the HARRF and SEWC flow will be diverted to recycled water use. During such low flow periods, however, the SEOO discharge will be comprised of a higher percentage of brine and cooling tower blowdown, including:

- up to 0.5 mgd of reverse osmosis brine from the proposed City of Escondido MFRO facility (which will be operated on a continuous basis),
- up to 1.4 mgd of cooling tower blowdown from the PEC,
- up to 0.07 mgd of reverse osmosis brine from the Stone Brewing Company, and
- up to 0.2 mgd of reverse osmosis brine from SEWC advanced water treatment facility.

Near-maximum brine flows could also occur during periods of wet weather when the SEWC advanced water treatment facilities and the MFRO are operating to divert recycled water to storage and offload peak flow discharged to the SEOO.

A total of four (4) initial dilution scenarios were posed to address the San Diego RWQCB requirements for the Initial Dilution Study and assess initial dilution for a potential range of seasonal SEOO operating conditions. Model scenarios assessed a range of projected future SEOO discharge flows and SEOO brine flows and superimposed these discharge flows and discharge salinities on the seasonal oceanographic conditions that would likely occur during the periods associated with the discharge flow scenarios. **Table 1** summarizes the four (4) model scenarios which were based on assignments for discharge rates and salinities as listed in **Table 2**.

Model Scenarios #1 through #4 in **Table 1** were posed to assess projected seasonal initial dilutions using a range of projected SEOO flow and salinity conditions listed in Table 2 superimposed on observed seasonal SEOO ocean density (temperature/salinity) data collected during 2013-2014 by MTS, as approved by the RWQCB. Model Scenarios #1 and #2 assess initial dilutions associated with maximum flow/maximum brine conditions during winter and spring conditions, while Scenarios #3 and #4 would assess minimum flow/maximum brine conditions during summer and fall conditions. For these model runs, all density profiles from the 2013-2014 SEOO ocean density data base were utilized for Plumes 20 and CORMIX v-12 initial dilution modeling. From this ensemble of initial dilution modeling results, a representative worst-month minimum initial dilution result was determined from among the winter, spring, summer and fall seasonal operating periods with maximum brine additions.

Table 1: Initial Dilution Model Scenarios SEOO Initial Dilution Study

Proposed Dilution Model Scenario	Flow Scenario	Ocean Density Profile	Combined SEOO Discharge Flow	Projected Salinity Concentration of Combined SEOO Discharge	Objective
#1	Maximum SEOO discharge flow w/Maximum brine discharges ^B	Winter 2013-2014 ^D	23.25 mgd ^A	1.34 psu ^C	Seasonally characterize projected SEOO initial dilutions for the projected range of discharge flow and salinity conditions
#2	Maximum SEOO discharge flow w/Maximum brine discharges ^B	Spring 2013-2014 ^D	23.25 mgd ^A	1.34 psu ^C	
#3	Minimum SEOO discharge flow w/Maximum brine discharges ^E	Summer 2013-2014 ^D	7.2 mgd ^E	1.88 psu ^F	
#4	Minimum SEOO discharge flow w/Maximum brine discharges ^E	Autumn 2013-2014 ^D	7.2 mgd ^E	1.88 psu ^F	

Table 1 Notes:

- A Maximum monthly average SEOO discharge flow permitted within Order Nos. R9-2018-0002 and R9-2018-0003. As documented within the Orders, this maximum SEOO discharge flow was used by the SWRCB in 2005 for purposes of computing the assigned SEOO initial dilution of 237:1.
- B Maximum allowable SEOO discharge of 23.25 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility. See Table 2.
- C Projected salinity of combined SEOO discharge during maximum 23.25 mgd discharge with maximum allowable brine discharges from the PEC, Stone Brewing Company, the City of Escondido MFRO, the SEJPA SEWC advanced water treatment facility. See Table 2.
- D Ocean density profile from available 2013-2014 monthly density profiles that is selected by MBI as being representative of seasonal oceanographic conditions. This includes monthly density profiles from December 2013, January 2014 and February 2014 to characterize a range of typical winter conditions, monthly profiles for March through May 2014 to characterize spring conditions, monthly profiles for June through August 2014 to characterize summer conditions, and monthly profiles from September through November 2014 to characterize the range of typical fall conditions.
- E Projected minimum SEOO discharge flows during times of peak recycled water demand. Includes maximum allowable brine discharges from the PEC, Stone Brewing Company, City of Escondido MFRO and SEJPA SEWC. See Table 2.
- F Estimated salinity of the combined SEOO discharge during conditions of minimum SEOO discharge flows and maximum brine contributions. See Table 2.

Table 2: Projected Discharge Flows and Salinities Maximum and Minimum SEOO Discharge Flows

Facility	Maximum SEOO Discharge Flows w/Maximum Brine Discharges Scenarios #1 and #2		Minimum SEOO Discharge Flows w/Maximum Brine Discharges Scenarios #3 and #4	
	Discharge Flow	Projected Salinity Concentration	Discharge Flow	Projected Salinity Concentration
HARRF secondary effluent	16.03 mgd ^A	1.0 psu ^B	5.0 mgd ^C	1.0 psu ^B
MFRO reverse osmosis brine	0.5 mgd ^D	4.5 psu ^D	0.5 mgd ^D	4.5 psu ^D
Palomar Energy Center cooling tower discharge	1.4 mgd ^E	3.0 psu ^E	1.4 mgd ^E	3.0 psu ^E
Stone Brewing Company reverse osmosis brine discharge	0.07 mgd ^F	4.5 psu ^F	0.07 mgd ^F	4.5 psu ^F
SEWC secondary effluent	5.15 ^G	1.2 psu ^G	0 ^H	---
SEWC reverse osmosis brine	0.2 ^I	5.0 psu ^I	0.2 ^I	5.0 psu ^I
Combined SEOO Discharge	23.25 ^J	1.34 psu ^K	7.17 mgd ^L	1.88 psu ^K

Table 2 Notes:

- A RWQCB Order No. R9-2018-0002 limits the total discharge from HARRF, the Palomar Energy Center, MFRO and Stone Brewing to a monthly average flow of 18 mgd. The HARRF secondary effluent discharge would be limited to a monthly average of 16.03 mgd if other discharging facilities are contributing flows to the Escondido Land Outfall as shown above.
- B Approximate HARRF secondary effluent salinity concentration. RWQCB Order No. R9-2010-0032 establishes a TDS effluent concentration limit of 1000 mg/L (approximately 1.0 psu) for HARRF recycled water.
- C Assumes a HARRF inflow of 14 mgd, less 9 mgd flow diverted to the HARRF tertiary treatment facility.
- D When operating at capacity, the City of Escondido MFRO facility reverse osmosis discharge is projected at 0.5 mgd with a total dissolved solids concentration of 4500 mg/L (approximately 4.5 psu).
- E RWQCB Order No. R9-2012-0015 (as amended) limits cooling tower blowdown flows from the Palomar Energy Center to 1.4 mgd. Discharge TDS concentrations vary but are typically on the order of 3000 mg/L (approximately 3.0 psu).
- F RWQCB Order No. R9-2014-0094 (as amended) limits the Stone Brewing Company reverse osmosis brine discharge to 0.07 mgd. Estimated salinity is approximately 4.5 psu.
- G Maximum allowable monthly average SEJPA discharge to the SEOO is 5.25 mgd. When SEWC reverse osmosis facilities are operating and contributing 0.2 mgd of brine, SEWC secondary effluent discharges to the SEOO would be limited to a monthly average of 5.05 mgd. Such a 5.05 mgd flow would be rare and limited to extended periods of wet weather, as typical SEWC inflows are on the order of 3 mgd.
- H SEJPA utilizes virtually 100 percent of its available recycled water supply during periods of peak irrigation demand.
- I When operating at full capacity, the SEWC reverse osmosis facility generates approximately 0.2 mgd of brine with a salinity concentration of roughly 5.0 psu.
- J Maximum allowable monthly average SEOO discharge flow per RWQCB Order Nos. R9-2018-0002 and R9-2018-0003.
- K Estimated salinity of the combined SEOO discharge flow the above-listed facility flows and salinities.
- L SEOO outfall flow assuming a HARRF influent flow of 14 mgd, 9 mgd of HARRF effluent diverted to recycled water production and brine/residuals discharges of 2.17 mgd.

3) Dilution Model Parameter Assignments and Dilution Output

The Visual Plumes (UM3) dilution model originally used to determine the minimum initial dilution of 237:1 in Order No. R9-2005-0100 utilizes nearly the same set of input parameters as the updated UM3 model, Plumes 20 with some minor exceptions. Therefore, the original 2005 Visual Plumes parameter assignments are adopted for Plumes 20 modeling of all four (4) scenarios in **Table 1**. Those parameter assignments are lifted from Appendix G of RWQCB, (2005) as follows:

- **Port diameter:** 2 inches. Section 1-3 of the Report of Waste Discharge for the San Elijo Water Reclamation Facility (RWD)
- **Port elevation:** 0.0 feet. Section 3-3 of the Report of Waste Discharge for the Hale Avenue Resource Recovery Facility indicates that the outfall lies on the ocean floor.
- **Vertical angle:** -5.0 degrees. Table 3-2 of the Report of Waste Discharge for the Hale Avenue Resource Recovery Facility.
- **Horizontal angle:** 0.0 degrees. The model does not have input abilities for a diffuser with ports facing various directions. A single direction for all ports was assigned. This will result in a conservative dilution factor.
- **Number of ports:** 200 ports per Section 1-3 of RWD
- **Port spacing:** 6 feet. Section 1-3 of RWD indicates that there are 100 ports on each side of the diffuser. The section also indicates that the ports are spaced every 12 feet. To account for two ports every 12 feet, the port spacing was entered as 6 ft, instead of the actual 12 feet (which would otherwise double the length of the diffuser).
- **Acute mix zone:** Not relevant, value does not affect dilution factor as defined by the SWRCB.
- **Chronic mix zone:** Not relevant, value does not affect dilution factor as defined by the SWRCB.
- **Port depth:** 140 feet. The 2003 and 2013-2014 density profile data bases were collected at monitoring station A-0.5-S where the local water depth is 140 ft. Note, the original 2005 Visual Plumes (UM3) modeling assumed a port depth of 148, (per Appendix G of RWQCB, 2005), which is the maximum depth of the SEOO diffuser.
- **Effluent flow:** 23.25 mgd. The total combined permitted flow from the San Elijo Water Reclamation Facility (5.25 mgd) and the Hale Avenue Resource Recovery Facility (18.0 mgd). Note that the actual capacity of the SEOO is 25.5 mgd.
- **Effluent salinity:** 1.2 psu - The most conservative value was selected from Table 2-3 of the Report of Waste Discharge for the Hale Avenue Resource Recovery Facility.
- **Effluent temperature:** 22.5 °C The most conservative value was selected from Table 2-4 of the Report of Waste Discharge for the Hale Avenue Resource Recovery Facility.

- **Effluent concentration:** Not relevant, input does not affect dilution factor.
- **Ambient data:** Monthly ambient data submitted to the Regional Water Quality Control Board for the SEOO (monitoring station AO.5S - closest to the diffuser) for the time frame between June 2003 through December 2003 was entered. The most conservative month was used to determine the minimum initial dilution factor (July 2003).
- **Far-field diffusion coefficient** - $0.0003 \text{ m}^{0.67}/\text{s}^2$ - recommended in the Visual Plumes manual as a conservative value.
- **Special Settings Tab, Farfield Diffusivity Option:** 4/3 Power Diffusivity was chosen based on the fact that the discharge is occurring in open water.
- **Special Settings Tab, Diffuser Port Contraction Coefficient:** 0.61 based on the use of cylindrical ports in the diffuser.
- **Special Settings Tab, Standard Light Adsorption Coefficient:** 0.16 is recommended in the Visual Plumes manual as a conservative value.

Regarding model output, the Plumes 20 initial dilution output variable is “*Dilutn*” while CORMIX v12 uses the symbol “*S*” to represent initial dilution. Both of these initial dilution output variables are *mixing ratios*, which represent the ratio of the total parts of a water sample per parts effluent contained in that sample. However the relevant dilution metric under the Ocean Plan is initial *dilution factor*, “*Dm*,” which is defined as parts seawater per parts effluent, (Appendix I, SWRCB, 2018). Mixing ratios, *Dilutn* and *S*, are related to initial dilution factor, *Dm*, by the following:

$$D_m = Dilutn - 1 = S - 1 \quad (1)$$

4) Plumes 20 Initial Dilution Results for Discharge Scenario #1: Maximum Discharge With Maximum Brine Additions for Winter Density Profiles

Initial dilution solutions for Scenario #1 using both Plumes 20 and CORMIX v-12 are plotted in **Figure 4.1**. These solutions are based on maximum allowable SEOO discharge of 23.25 mgd, containing maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility, resulting in a discharge salinity of 1.34 psu. These discharge inputs are applied to the monthly water column density profiles in **Appendix A** for winter conditions from December 2013 through February 2014. Print-outs of the Plumes 20 and CORMIX-v12 maximum brine additions solution files for each of these three winter months are found in **Appendix B** along with graphical outputs of the individual initial dilution factors, D_m , as a function of depth. Inspection of **Figure 4.1** reveals that the Plumes 20 solutions surpass the NPDES-assigned minimum initial dilution of $D_m = 237$ using the density profiles for the months of December 2013 (when $D_m = 325.2$) and January 2014, (when $D_m = 341.6$). However, Plumes 20 predicts the assent of the plume is arrested very close to the seabed at a depth of 114.7 ft with the February 2014 density profiles, where initial dilution reaches only $D_m = 76.85$. Inspection of the density profile for February 2014 in **Appendix A** is extremely unusual, with an approximately isothermal/isohaline distribution between the seabed and the sea surface, as if the entire water column were a single-layer, homogeneous water mass. The mean water column density of the February 2014 density profile was $\langle \rho \rangle = 1.02480 \text{ g/cm}^3$ with a standard deviation of only $\sigma = 0.00003 \text{ g/cm}^3$ between the seabed and sea surface, essentially indicating a uniform water mass. Furthermore, the February 2014 density profile is only weakly stable with the density at the seabed exceeding that at the sea surface by only 0.00005 g/cm^3 . This fact provokes the hypothesis that the extremely marginal stability of February 2014 density profile may have induced a numerical instability within the Plumes 20 code, causing it to truncate the initial dilution computational sequence at a depth of 114.7 ft (only 25.3 ft above the bottom), where initial dilution had only reached 76.85:1. To test this hypothesis, the CORMIX v-12 expert system model (which is immune to numerical instability) ran Scenario #3 on the February 2014 density profile using a mean water column density of $\langle \rho \rangle = 1,024.8 \text{ kg/m}^3$, (equivalent to 1.02480 g/cm^3). The CORMIX v-12 prediction file for February 2014, (cf. Section B.3 in **Appendix B**) indicates that initial dilution reached $D_m = 379.9$ at a depth of 46.2 ft. This result appears more sensible and is in line with the other Scenario #1 initial dilution results obtained with Plumes 20 using the December 2013 and January 2014 density profiles that displayed mean temperatures and salinities comparable to those of the February 2014 density profile.




Figure 4.1: Plumes 20 and CORMIX v-12 initial dilution solutions for Scenario #1 based on maximum allowable SEOO discharge of 23.25 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility applied to the monthly water column density profiles in **Appendix A** under winter conditions from December 2013 through February 2014. The CORMIX v-12 solution for February 2014 oceanographic conditions is shown above, as the nearly homogeneous nature of ocean density throughout the depth profile that existed during February 2014 caused the Plumes 20 simulation to truncate prior to converging on an appropriate initial dilution solution.

5) Plumes 20 Initial Dilution Results for Discharge Scenario #2: Maximum Discharge With Maximum Brine Additions for Spring Density Profiles

Initial dilution solutions for Scenario #2 using the Plumes 20 dilution model are plotted in **Figure 5.1**. These solutions are based on maximum allowable SEOO discharge of 23.25 mgd, containing maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility resulting in a discharge salinity of 1.34 psu. These discharge inputs are applied to the monthly water column density profiles in **Appendix A** for spring conditions from March through May 2014. Print-outs of the Plumes 20 maximum brine additions solution files for each of these three spring months are found in **Appendix C** along with graphical outputs of the individual initial dilution factors, D_m , as a function of depth. Inspection of **Figure 5.1** reveals that the Plumes 20 solution for Scenario #2 during March 2014 achieves an initial dilution of $D_m = 237$ at a depth of 24.4 ft, which is consistent with the minimum initial dilution of 237:1 assigned within Order Nos. R9-2018-0002 and R9-2018-0003. Frick and Roberts, (2016). All the remaining Plumes 20 solutions for Scenario #2 surpass the certified minimum initial dilution of 237:1 using the density profiles for the months of April 2014 (when $D_m = 326.8$) and May 2014, (when $D_m = 278.2$). With the April 2014 density profiles, the plume comes close to broaching the sea surface when initial dilution is arrested at a depth of 2.46 ft., (cf. Section C.2 in **Appendix C**).




Figure 5.1: Plumes 20 initial dilution solutions for Scenario #2 based on maximum allowable SEOO discharge of 23.25 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility applied to the monthly water column density profiles in **Appendix A** under spring conditions from March 2014 through May 2014.

6) Plumes 20 Initial Dilution Results for Discharge Scenario #3: Minimum Discharge With Maximum Brine Additions for Summer Density Profiles

Initial dilution solutions for Scenario #3 using the Plumes 20 dilution model are plotted in **Figure 6.1**. These solutions are based on historic minimum SEOO discharge of 7.2 mgd, containing maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility, resulting in a discharge salinity of 1.88 psu. These discharge inputs are applied to the monthly water column density profiles in **Appendix A** for summer conditions from June through August 2014. Print-outs of the Plumes 20 maximum brine additions solution files for each of these three summer months are found in **Appendix D** along with graphical outputs of the individual initial dilution factors, D_m , as a function of depth. All the Plumes 20 solutions for Scenario #3 significantly exceed the minimum initial dilution of 237:1 assigned within Order Nos. R9-2018-0002 and R9-2018-0003, reaching $D_m = 523.7$ at a depth of 28.1 ft during June 2014; falling somewhat to $D_m = 452.8$ at a depth of 37.4 ft during July 2014, and declining further to $D_m = 422.6$ at a depth of 46.8 ft during August 2014. The steady decline in initial dilution throughout the summer months is due to progressive warming and deepening of the surface mixed layer, (cf. density profiles for June-August 2014 in **Appendix A**), which in turn arrests the ascent of the plume at deeper depths, causing initial dilution to stop closer to the bottom as the summer wears on.




Figure 6.1: Plumes 20 initial dilution solutions for Scenario #3 based on historic minimum SEOO discharge of 7.2 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility, resulting in a discharge salinity of 1.88 psu. These discharge inputs are applied to the monthly water column density profiles in **Appendix A** under summer conditions from June 2014 through August 2014.

7) Plumes 20 Initial Dilution Results for Discharge Scenario #4: Minimum Discharge With Maximum Brine Additions for Autumn Density Profiles

Initial dilution solutions for Scenario #4 using the Plumes 20 dilution model are plotted in **Figure 7.1**. These solutions are based on maximum allowable SEOO discharge of 7.2 mgd, containing maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility, resulting in a discharge salinity of 1.88 psu. These discharge inputs are applied to the monthly water column density profiles in **Appendix A** for autumn conditions from September and October 2014 and November 2013. Print-outs of the Plumes 20 maximum brine additions solution files for each of these three autumn months are found in **Appendix E** along with graphical outputs of the individual initial dilution factors, D_m , as a function of depth. All the Plumes 20 solutions for Scenario #4 result in initial dilutions that are significantly higher than the minimum initial dilution of 237:1 assigned in Order Nos. R9-2018-0002 and R9-2018-0003. Simulated Scenario #4 initial dilutions reach $D_m = 509.9$ at a depth of 33.1 ft during September 2014; dropping to $D_m = 298.5$ at a depth of 70.6 ft during October 2014, while during the previous November 2013 initial dilution reached $D_m = 510.7$ at a depth of 24.2 ft.




Figure 7.1: Plumes 20 initial dilution solutions for Scenario #4 based on historic minimum SEOO discharge of 7.2 mgd with maximum allowable cooling tower discharge from the PEC and maximum brine discharges from Stone Brewing Company, the City of Escondido MFRO and the SEJPA SEWC advanced water treatment facility applied to the monthly water column density profiles in [Appendix A](#) under autumn conditions from September 2014 through November 2014.

8) Conclusions

Table 3 summarizes the initial dilution simulations presented herein. Initial dilution modeling of Scenarios #1 and #2 demonstrate that MFRO operations, brine discharges, and other potential SEOO discharge operations will not result in a reduction in SEOO dilution during periods of maximum discharge flows, which would occur in winter or spring oceanographic conditions. Under winter conditions and maximum SEOO discharge flows (Scenario #1), SEOO initial dilutions are projected to exceed 325:1. Worst case conditions under maximum discharge flows (represented by Model Scenario #2) would occur during spring months (e.g., March 2014 density conditions) when the SEOO initial dilution is projected at 237:1 (the value currently assigned to the SEOO to represent maximum discharge conditions and minimum initial dilution). Initial dilutions during other spring months are projected to exceed 278:1 (see **Figure 5.1**).

Discharge conditions (e.g., reduced SEOO discharge flows but higher brine contributions) during periods of significant recycled water demand are projected to result in a significant improvement in SEOO initial dilution. As shown in **Figure 6.1**, Scenario #3 summer discharge conditions are projected to result in SEOO initial dilutions that exceed 422:1. During fall conditions (Scenario #4), SEOO initial dilutions are projected to exceed 298:1.

On the basis of these modeling results, it is concluded that no change to the presently assigned SEOO minimum month initial dilution of 237:1 is warranted. SEOO initial dilution is projected to remain higher than the NPDES assigned value throughout the projected range of SEOO discharge flows, discharge salinities, and seasonal oceanographic conditions.

Table 3: Summary of Initial Dilution Simulations			
Model Scenario	Simulated SEOO Discharge Flow Conditions	Simulated Ocean Density Profile	Projected Initial Dilution
Baseline Condition Determined by RWQCB/SWRCB Modeling ^A	Maximum SEOO discharge flow	2003-2004	237:1 ^A
Scenario #1	Maximum SEOO discharge flow w/Maximum brine discharges	December 2013	325:1 ^{B,C}
		January 2014	342:1 ^{B,C}
		February 2014	380:1 ^{B,C}
Scenario #2	Maximum SEOO discharge flow w/Maximum brine discharges	March 2013	237:1 ^{C,E,F}
		April 2013	327:1 ^{C,E}
		May 2013	278:1 ^{C,E}
Scenario #3	Minimum SEOO discharge flow w/Maximum brine discharges	June 2014	524:1 ^{C,G}
		July 2014	453:1 ^{C,G}
		August 2014	423:1 ^{C,G}
Scenario #4	Minimum SEOO discharge flow w/Maximum brine discharges	September 2014	510:1 ^{C,H}
		October 2014	298:1 ^{C,H}
		November 2013	511:1 ^{C,H}

A As documented in Order No. R9-2005-0139 and R9-2005-0100. This 237:1 initial dilution value has been carried over and applied to the SEOO discharges regulated under RWQCB Order Nos. R9-2018-0002 and R9-2018-0003.
 B See **Figure 4-1**.
 C Solution from Plumes 20 initial dilution simulation.
 D Solution from CORMIX v-12, as Plumes 20 failed to properly converge on a realistic solution due to an unusual oceanographic conditions (constant ocean density throughout all depths).
 E See **Figure 5-1**.
 F The April 2013 oceanographic, discharge flow, and discharge salinity conditions are representative of "minimum average month" conditions similar to those used by the RWQCB/SWRCB to assign the 237:1 initial dilution within Order Nos. R9-2018-0002 and R9-2018-0003.
 G See **Figure 6-1**.
 H See **Figure 7-1**.



9) References:



- Baumgartner, D. J., Frick, W. E., and Roberts, P. J. W. (1994). "Dilution Models for Effluent Discharges (Third Edition)." U.S. Environmental Protection Agency, Office of Research and Development, EPA/600/R-94/086
- Deser, C., Alexander, M., Xie, S., and A. Phillips, 2010. "Sea Surface Temperature Variability: Patterns and Mechanisms". *Annual Review of Marine Science*. 2 (1): 115–143, doi:10.1146/annurev-marine-120408-151453. PMID 21141660
- Doneker, R. L., and Jirka, G. H. (1999). "Discussion of mixing of inclined dense jets" by Roberts, P. J. W., Ferrier, A., and Daviero, G." (1997)." *J. Hydraul. Eng.*, 125(3), 317–319.
- Doneker, R. L. and Jirka, G. H., 2022, "CORMIX User Manual." MixZon, Portland, Oregon. Updated February 2022.
- Frick, W.E., Roberts, P., Davis, L., Keyes, J., Baumgartner, D., George, K., 2003, "Dilution models for effluent discharges, Forth Addition", U.S. Environmental Protection Agency, Standards and Applied Science Division Office of Science and Technology, 148 pp.
- Frick, W., Ahmed, A., George, K., Laputz, A., Pelletie, G., and Roberts, P. (2010). "On Visual Plumes and Associated Applications." MWWD 2010 6th International Conference on Marine Waste Water Discharges and Coastal Environment, C. Avanzini, ed. Langkawi, Malaysia.
- Frick, W. E., and Roberts, P. J. W., 2016, "Visual Plumes 2016: An Updated Public-Domain Plume Model Suite." Proc., International Symposium on Outfall Systems, ISOS2016, IWA. 10 - 13 May 2016
- Jenkins, S., A. and M. Shatila, 2019, "Plumes UM3 Dilution Modeling Assessment of the San Juan Creek Ocean Outfall", submitted to South Orange County Wastewater Authority, submitted by Michael Baker International, San Diego, 101 pp
- Qiu, B., Niklas S., and S. Chen, 2007, "Coupled Decadal Variability in the North Pacific: An Observationally Constrained Idealized Model". *Journal of Climate*. 20 (14): 360220. doi:10.1175/JCLI4190.1
- RWQCB, 2005, Waste Discharge Requirements for the San Elijo Joint Powers Authority, San Elijo Water Reclamation Facility Discharge to the Pacific Ocean via the San Elijo Ocean Outfall, NPDES No. CA0107999; Order No. R9-2005-0100, California Regional Water Quality Control Board, San Diego Region, 108 pp.
- RWQCB, 2017, California Regional Water Quality Control Board, Los Angeles Region, "Waste Discharge Requirements and National Pollution Discharge Elimination System Permit for City of Los Angeles Hyperion Treatment Plant Discharge to the Pacific Ocean," NPDES No. CA-0109991, Order No. R4-2017-0045, 180 pp.
- RWQCB, 2018, Waste Discharge Requirements for the San Elijo Joint Powers Authority, San Elijo Water Reclamation Facility Discharge to the Pacific Ocean through the San Elijo Ocean Outfall, NPDES No. CA0107999; Order No. R9-2018-0003, California Regional Water Quality Control Board, San Diego Region, 132 pp.



Walker, L., 2016, "Hyperion Water Reclamation Plant 5-Mile Outfall Dilution Study," submitted to Los Angeles Regional Water Quality Control Board, April, 2016, 40 pp



Walker, L., 2020, "HWRP Recycle Scenarios Compliance Assessment," submitted to Los Angeles Department of Sanitation, 24 September, 2020, 19 pp



APPENDIX A:
Temperature-Salinity-Density Profiles Used in the Updated SEOO
Minimum Initial Dilution Study based on Monthly Water Column
Monitoring from November 2013 Through October 2014















APPENDIX B:

Plumes 20 Initial Dilution Results for Discharge Scenario #1: Maximum Discharge Rate (23.25 mgd) with Maximum Brine Additions based on Winter Density Profiles from December 2013 Through February 2014

B.1 Maximum SEOO Discharge with Maximum Brine Additions for December 2013 Density Profiles

Project "C:\Plumes20\Max-SEOO_Dec2013_Max-Brine_v2" memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/19/2022 1:15:14 PM

Case 1; ambient file C:\Plumes20\Max-SEOO_Dec2013_Max-Brine_v2.001.db; Diffuser table record 1

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m0.67/s2	sigma-T
0.0	0.0	0.0	33.38	15.95	0.0	0.0	0.0	0.0	0.0	24.53331
3.048	0.0	0.0	33.38	15.95	0.0	0.0	0.0	0.0	0.0	24.53421
6.096	0.0	0.0	33.42	15.94	0.0	0.0	0.0	0.0	0.0	24.57148
9.143	0.0	0.0	33.45	15.94	0.0	0.0	0.0	0.0	0.0	24.58970
12.19	0.0	0.0	33.46	15.94	0.0	0.0	0.0	0.0	0.0	24.60306
15.24	0.0	0.0	33.44	15.88	0.0	0.0	0.0	0.0	0.0	24.59631
18.29	0.0	0.0	33.39	15.78	0.0	0.0	0.0	0.0	0.0	24.58401
21.33	0.0	0.0	33.31	15.60	0.0	0.0	0.0	0.0	0.0	24.55858
24.38	0.0	0.0	33.44	15.59	0.0	0.0	0.0	0.0	0.0	24.66083
27.43	0.0	0.0	33.31	15.20	0.0	0.0	0.0	0.0	0.0	24.65221
30.48	0.0	0.0	32.99	14.39	0.0	0.0	0.0	0.0	0.0	24.57462
33.53	0.0	0.0	32.96	14.04	0.0	0.0	0.0	0.0	0.0	24.62988
36.57	0.0	0.0	32.96	14.04	0.0	0.0	0.0	0.0	0.0	24.62988
39.62	0.0	0.0	33.00	14.00	0.0	0.0	0.0	0.0	0.0	24.66660
42.67	0.0	0.0	33.00	14.00	0.0	0.0	0.0	0.0	0.0	24.66660

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	23.250	1.3400	22.500	1200.0

Simulation:

Froude No: 40.98; Strat No: 4.78E-6; Spcg No: 14.05; k: 4.12E+5; eff den (σ_{mT}) -1.267032; eff vel 4.119(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (σ_{mT})	Dilutn ()	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.340	-1.26703	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.656	4.928	1.67149	1.125	0.036	0.0	0.04207; bottom hit;
15	140.0	0.0	2.292	11.73	7.22767	1.476	0.150	0.0	0.05822;
30	140.0	0.0	3.078	17.19	11.6947	1.977	0.312	0.0	0.07818;
45	140.0	0.0	4.136	21.25	15.0168	2.652	0.531	0.0	0.1050;
60	140.0	0.0	5.559	24.27	17.4889	3.561	0.827	0.0	0.1412;
75	140.0	0.0	7.475	26.52	19.3286	4.784	1.225	0.0	0.1899;
90	140.0	0.0	10.05	28.18	20.6975	6.430	1.761	0.0	0.2553;
105	139.9	0.0	13.51	29.42	21.7158	8.645	2.481	0.0	0.3433;
120	139.9	0.0	18.15	30.34	22.4731	11.63	3.449	0.0	0.4611;
130	139.8	0.0	21.97	30.81	22.8571	14.09	4.244	0.0	0.5580; merging;
135	139.7	0.0	23.70	30.96	22.9863	15.17	4.621	0.0	0.6019;
150	139.5	0.0	27.92	31.26	23.2333	17.79	5.645	0.0	0.7091;
165	139.2	0.0	31.46	31.45	23.3910	19.99	6.574	0.0	0.7991;
180	138.9	0.0	34.63	31.60	23.5078	22.00	7.454	0.0	0.8796;
195	138.5	0.0	37.56	31.71	23.6018	23.94	8.309	0.0	0.9541;
210	138.0	0.0	40.35	31.81	23.6822	25.90	9.159	0.0	1.0250;
225	137.4	0.0	43.07	31.89	23.7539	27.93	10.02	0.0	1.0940;
240	136.7	0.0	45.79	31.97	23.8203	30.12	10.91	0.0	1.1630;
255	135.9	0.0	48.59	32.05	23.8837	32.56	11.84	0.0	1.2341;
270	134.9	0.0	51.57	32.13	23.9456	35.35	12.83	0.0	1.3100;
285	133.5	0.0	54.91	32.20	24.0074	38.67	13.90	0.0	1.3946;
300	131.9	0.0	58.82	32.28	24.0704	42.75	15.08	0.0	1.4939;
315	129.6	0.0	63.67	32.36	24.1353	47.97	16.41	0.0	1.6171;
330	126.6	0.0	70.20	32.44	24.2028	55.04	17.95	0.0	1.7830;
345	122.0	0.0	79.90	32.52	24.2726	65.30	19.82	0.0	2.0295;
360	114.9	0.0	95.71	32.61	24.3435	81.35	22.17	0.0	2.4311;
375	103.0	0.0	122.3	32.70	24.4116	107.6	25.13	0.0	3.1071;
390	85.86	0.0	162.4	32.81	24.4636	144.8	28.36	0.0	4.1259;
405	63.31	0.0	215.0	32.95	24.5049	194.9	31.43	0.0	5.4622;
420	31.02	0.0	302.1	33.07	24.5289	262.3	34.88	0.0	7.6726;
428	9.040	0.0	363.6	33.12	24.5366	307.3	36.81	0.0	9.2357; matched energy
430	2.776	0.0	387.9	33.13	24.5368	319.8	37.34	0.0	9.8520; trap level;
431	-0.542	0.0	402.5	33.14	24.5369	326.2	37.62	0.0	10.225; surface;

Horiz plane projections in effluent direction: radius(m): 0.0; Cl(m): 11.467


Lmz(m): 11.467

forced entrain 1 0.0 42.84 10.22 0.0842

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 33.3750

;

1:15:14 PM. amb fills: 4



B.2 Maximum SEOO Discharge with Maximum Brine Additions for January 2014 Density Profiles

Project "C:\Plumes20\Max-SEOO_Jan2014_Max-Brine"
 memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/19/2022 11:52:11 AM

Case 1; ambient file C:\Plumes20\Max-SEOO_Jan2014_Max-Brine.001.db; Diffuser table record 1:

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m0.67/s2	sigma-T
0.0	0.0	0.0	34.60	15.44	0.0	0.0	0.0	0.0	0.0	25.58725
3.048	0.0	0.0	34.60	15.44	0.0	0.0	0.0	0.0	0.0	25.58650
6.096	0.0	0.0	34.58	15.24	0.0	0.0	0.0	0.0	0.0	25.61719
9.143	0.0	0.0	34.62	15.21	0.0	0.0	0.0	0.0	0.0	25.64963
12.19	0.0	0.0	34.56	15.17	0.0	0.0	0.0	0.0	0.0	25.62068
15.24	0.0	0.0	34.57	15.12	0.0	0.0	0.0	0.0	0.0	25.63290
18.29	0.0	0.0	34.52	15.06	0.0	0.0	0.0	0.0	0.0	25.61071
21.33	0.0	0.0	34.49	14.97	0.0	0.0	0.0	0.0	0.0	25.61184
24.38	0.0	0.0	34.48	14.84	0.0	0.0	0.0	0.0	0.0	25.63150
27.43	0.0	0.0	34.45	14.73	0.0	0.0	0.0	0.0	0.0	25.62653
30.48	0.0	0.0	34.37	14.38	0.0	0.0	0.0	0.0	0.0	25.64443
33.53	0.0	0.0	34.30	14.15	0.0	0.0	0.0	0.0	0.0	25.64074
36.57	0.0	0.0	34.30	14.15	0.0	0.0	0.0	0.0	0.0	25.64074
39.62	0.0	0.0	34.31	14.11	0.0	0.0	0.0	0.0	0.0	25.65294
42.67	0.0	0.0	34.31	14.11	0.0	0.0	0.0	0.0	0.0	25.65294

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	23.250	1.3400	22.500	1200.0

Simulation:

Froude No: 40.23; Strat No: 2.27E-6; Spcg No: 14.05; k: 4.12E+5; eff den (sigmaT) -1.267032;
 eff vel 4.119(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn ()	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.340	-1.26703	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.656	5.080	1.78347	1.125	0.0359	0.0	0.04207; bottom hit;
15	140.0	0.0	2.292	12.16	7.54668	1.475	0.150	0.0	0.05821;
30	140.0	0.0	3.077	17.85	12.1815	1.976	0.312	0.0	0.07817;
45	140.0	0.0	4.135	22.08	15.6296	2.651	0.531	0.0	0.1050;
60	140.0	0.0	5.558	25.22	18.1962	3.559	0.826	0.0	0.1412;
75	140.0	0.0	7.473	27.56	20.1067	4.781	1.224	0.0	0.1898;
90	140.0	0.0	10.05	29.29	21.5286	6.425	1.760	0.0	0.2552;
105	139.9	0.0	13.51	30.58	22.5865	8.639	2.480	0.0	0.3431;
120	139.9	0.0	18.14	31.54	23.3733	11.62	3.447	0.0	0.4608;
131	139.8	0.0	22.26	32.06	23.7981	14.28	4.304	0.0	0.5655; merging;
135	139.7	0.0	23.58	32.18	23.8994	15.10	4.593	0.0	0.5990;
150	139.5	0.0	27.68	32.49	24.1530	17.65	5.587	0.0	0.7032;
165	139.2	0.0	31.13	32.69	24.3163	19.81	6.491	0.0	0.7907;
180	138.9	0.0	34.22	32.83	24.4378	21.79	7.348	0.0	0.8691;
195	138.5	0.0	37.08	32.95	24.5360	23.70	8.183	0.0	0.9418;
210	138.0	0.0	39.80	33.06	24.6202	25.63	9.014	0.0	1.0109;
225	137.5	0.0	42.45	33.15	24.6954	27.65	9.856	0.0	1.0783;
240	136.8	0.0	45.10	33.23	24.7653	29.82	10.73	0.0	1.1457;
255	135.9	0.0	47.84	33.31	24.8319	32.24	11.64	0.0	1.2152;
270	134.9	0.0	50.77	33.39	24.8972	35.03	12.61	0.0	1.2896;
285	133.6	0.0	54.05	33.47	24.9625	38.34	13.66	0.0	1.3728;
300	131.9	0.0	57.90	33.55	25.0289	42.42	14.82	0.0	1.4707;
315	129.7	0.0	62.70	33.64	25.0976	47.66	16.13	0.0	1.5926;
330	126.7	0.0	69.10	33.72	25.1691	54.73	17.64	0.0	1.7552;
345	122.3	0.0	78.35	33.81	25.2437	64.87	19.43	0.0	1.9901;
360	115.4	0.0	92.95	33.91	25.3212	80.55	21.65	0.0	2.3609;
375	104.0	0.0	117.6	34.01	25.3992	106.5	24.45	0.0	2.9870;
390	87.79	0.0	154.0	34.11	25.4607	143.4	27.36	0.0	3.9105;
405	65.86	0.0	206.7	34.20	25.5031	193.0	30.30	0.0	5.2508;
420	35.74	0.0	279.0	34.29	25.5337	259.7	33.36	0.0	7.0866;
431	7.488	0.0	342.8	34.35	25.5521	322.9	35.55	0.0	8.7075;
434	-1.466	0.0	371.8	34.36	25.5542	342.6	36.18	0.0	9.4445; surface;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 11.027


Lmz(m): 11.027

forced entrain 1 0.0 43.12 9.444 0.0697

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 34.5995

;

11:52:11 AM. amb fills: 4



Lmp = 99999.00 Lbp = 99999.00

NON-DIMENSIONAL PARAMETERS

FRO = 4.78 FRD0 = 2.23 R = 99999.00 PL = 27.17
(slot) (port/nozzle)

RECOMPUTED SOURCE CONDITIONS FOR ALTERNATING JETS OR RISER GROUPS:

Momentum fluxes: m0 = 0.9613E-03 M0 = 0.3516E+00
IQ=B = 0.008 IM = 0.12 lm = 99999.00 lmp = 99999.00
LQ = 2.358 LM = 0.91 lm = 99999.00 lmp = 99999.00
Properties of riser group with 1 ports/nozzles each:
U0 = 0.345 D0 = 0.043 A0 = 0.001 THETA = 90.00
FRO = 7.69 FRD0 = 3.32 R = 99999.00
(slot) (riser group)

FLOW CLASSIFICATION

222
2 Flow class (CORMIX2) = MU1V 2
2 Applicable layer depth HS = 33.53 2
222

MIXING ZONE / TOXIC DILUTION / REGION OF INTEREST PARAMETERS

C0 = 0.1000E+03 CUNITS= %
NTOX = 0
NSTD = 0
REGMZ = 0
XINT = 5000.00 XMAX = 5000.00

X-Y-Z COORDINATE SYSTEM:

ORIGIN is located at the bottom and the diffuser mid-point:
2255.52 m from the LEFT bank/shore.
X-axis points downstream, Y-axis points to left, Z-axis points upward.
NSTEP = 100 display intervals per module

BEGIN MOD101: DISCHARGE MODULE (SINGLE PORT AT DIFFUSER CENTER)

X	Y	Z	S	C	BV	BH	Uc	TT
0.00	0.00	0.67	1.0	0.100E+03	0.02	0.02	0.251	.00000E+00

END OF MOD101: DISCHARGE MODULE (SINGLE PORT AT DIFFUSER CENTER)

BEGIN CORJET (MOD110): JET/PLUME NEAR-FIELD MIXING REGION

Jet/plume transition motion in weak crossflow.

Zone of flow establishment: THETAE= 90.00 SIGMAE= 0.00
LE = 0.21 XE = 0.00 YE = 0.00 ZE = 0.88

Profile definitions:

BV = Gaussian 1/e (37%) width, in vertical plane normal to trajectory

BH = before merging: Gaussian 1/e (37%) half-width in horizontal plane
 normal to trajectory

after merging: top-hat half-width in horizontal plane
 parallel to diffuser line

S = hydrodynamic centerline dilution

C = centerline concentration (includes reaction effects, if any)

Uc = Local centerline excess velocity (above ambient)

TT = Cumulative travel time

X	Y	Z	S	C	BV	BH	Uc	TT
0.00	0.00	0.88	1.0	0.100E+03	0.02	0.02	0.251	.00000E+00
0.00	0.00	0.88	1.0	0.100E+03	0.02	0.02	0.251	.25233E-02
0.00	0.00	1.17	3.3	0.301E+02	0.06	0.06	0.251	.80486E+00
0.00	0.00	1.45	7.2	0.140E+02	0.09	0.09	0.245	.18765E+01
0.00	0.00	1.47	10.0	0.100E+02	0.11	182.99	0.172	.19489E+01
0.00	0.00	2.02	16.9	0.592E+01	0.18	183.06	0.185	.50071E+01
0.00	0.00	2.31	20.6	0.485E+01	0.22	183.10	0.186	.65491E+01
0.00	0.00	2.59	24.4	0.410E+01	0.26	183.14	0.186	.80876E+01
0.00	0.00	2.88	28.2	0.355E+01	0.30	183.18	0.186	.96247E+01
0.00	0.00	3.17	32.0	0.313E+01	0.34	183.22	0.186	.11161E+02
0.00	0.00	3.45	35.8	0.280E+01	0.38	183.26	0.186	.12697E+02
0.00	0.00	3.74	39.6	0.253E+01	0.42	183.30	0.186	.14233E+02
0.00	0.00	4.02	43.3	0.231E+01	0.46	183.34	0.186	.15769E+02
0.00	0.00	4.31	47.1	0.212E+01	0.50	183.38	0.186	.17305E+02
0.00	0.00	4.60	50.9	0.196E+01	0.54	183.42	0.186	.18841E+02
0.00	0.00	4.88	54.7	0.183E+01	0.58	183.46	0.186	.20377E+02
0.00	0.00	5.17	58.5	0.171E+01	0.62	183.50	0.186	.21913E+02
0.00	0.00	5.45	62.3	0.161E+01	0.66	183.54	0.186	.23449E+02
0.00	0.00	5.74	66.1	0.151E+01	0.70	183.58	0.186	.24984E+02
0.00	0.00	6.03	69.9	0.143E+01	0.74	183.62	0.186	.26520E+02
0.00	0.00	6.31	73.7	0.136E+01	0.78	183.66	0.186	.28056E+02
0.00	0.00	6.60	77.5	0.129E+01	0.82	183.70	0.186	.29592E+02
0.00	0.00	6.88	81.3	0.123E+01	0.86	183.74	0.186	.31128E+02
0.00	0.00	7.17	85.0	0.118E+01	0.91	183.79	0.186	.32664E+02
0.00	0.00	7.46	88.8	0.113E+01	0.95	183.83	0.186	.34200E+02
0.00	0.00	7.74	92.6	0.108E+01	0.99	183.87	0.186	.35736E+02
0.00	0.00	8.03	96.4	0.104E+01	1.03	183.91	0.186	.37278E+02
0.00	0.00	8.31	100.2	0.998E+00	1.07	183.95	0.186	.38814E+02
0.00	0.00	8.60	104.0	0.961E+00	1.11	183.99	0.186	.40350E+02
0.00	0.00	8.89	107.8	0.928E+00	1.15	184.03	0.186	.41886E+02
0.00	0.00	9.17	111.6	0.896E+00	1.19	184.07	0.186	.43422E+02
0.00	0.00	9.46	115.4	0.867E+00	1.23	184.11	0.186	.44958E+02
0.00	0.00	9.74	119.2	0.839E+00	1.27	184.15	0.186	.46493E+02
0.00	0.00	10.03	123.0	0.813E+00	1.31	184.19	0.186	.48029E+02
0.00	0.00	10.32	126.8	0.789E+00	1.35	184.23	0.186	.49565E+02
0.00	0.00	10.60	130.6	0.766E+00	1.39	184.27	0.186	.51101E+02
0.00	0.00	10.89	134.3	0.744E+00	1.43	184.31	0.186	.52637E+02
0.00	0.00	11.17	138.1	0.724E+00	1.47	184.35	0.186	.54173E+02
0.00	0.00	11.46	141.9	0.705E+00	1.51	184.39	0.186	.55702E+02
0.00	0.00	11.74	145.7	0.686E+00	1.55	184.43	0.186	.57238E+02

0.00	0.00	12.03	149.5	0.669E+00	1.59	184.47	0.186	.58774E+02
0.00	0.00	12.32	153.3	0.652E+00	1.63	184.51	0.186	.60310E+02
0.00	0.00	12.60	157.1	0.637E+00	1.67	184.55	0.186	.61846E+02
X	Y	Z	S	C	BV	BH	Uc	TT
0.00	0.00	12.89	160.9	0.622E+00	1.71	184.59	0.186	.63382E+02
0.00	0.00	13.17	164.7	0.607E+00	1.75	184.63	0.186	.64918E+02
0.00	0.00	13.46	168.5	0.594E+00	1.79	184.67	0.186	.66453E+02
0.00	0.00	13.75	172.2	0.581E+00	1.83	184.71	0.186	.67989E+02
0.00	0.00	14.03	176.0	0.568E+00	1.87	184.75	0.186	.69525E+02
0.00	0.00	14.32	179.8	0.556E+00	1.91	184.79	0.186	.71061E+02
0.00	0.00	14.60	183.6	0.545E+00	1.95	184.83	0.186	.72597E+02
0.00	0.00	14.89	187.4	0.534E+00	1.99	184.87	0.186	.74133E+02
0.00	0.00	15.18	191.2	0.523E+00	2.03	184.91	0.186	.75669E+02
0.00	0.00	15.46	195.0	0.513E+00	2.08	184.96	0.186	.77205E+02
0.00	0.00	15.75	198.8	0.503E+00	2.12	185.00	0.186	.78741E+02
0.00	0.00	16.03	202.6	0.494E+00	2.16	185.04	0.186	.80276E+02
0.00	0.00	16.32	206.4	0.485E+00	2.20	185.08	0.186	.81812E+02
0.00	0.00	16.60	210.2	0.476E+00	2.24	185.12	0.186	.83348E+02
0.00	0.00	16.89	213.9	0.467E+00	2.28	185.16	0.186	.84884E+02
0.00	0.00	17.18	217.7	0.459E+00	2.32	185.20	0.186	.86420E+02
0.00	0.00	17.46	221.5	0.451E+00	2.36	185.24	0.186	.87956E+02
0.00	0.00	17.75	225.3	0.444E+00	2.40	185.28	0.186	.89498E+02
0.00	0.00	18.04	229.1	0.436E+00	2.44	185.32	0.186	.91034E+02
0.00	0.00	18.32	232.9	0.429E+00	2.48	185.36	0.186	.92570E+02
0.00	0.00	18.61	236.7	0.422E+00	2.52	185.40	0.186	.94106E+02
0.00	0.00	18.89	240.5	0.416E+00	2.56	185.44	0.186	.95642E+02
0.00	0.00	19.18	244.3	0.409E+00	2.60	185.48	0.186	.97178E+02
0.00	0.00	19.47	248.1	0.403E+00	2.64	185.52	0.186	.98720E+02
0.00	0.00	19.75	251.9	0.397E+00	2.68	185.56	0.186	.10026E+03
0.00	0.00	20.04	255.7	0.391E+00	2.72	185.60	0.186	.10179E+03
0.00	0.00	20.32	259.5	0.385E+00	2.76	185.64	0.186	.10333E+03
0.00	0.00	20.61	263.3	0.380E+00	2.80	185.68	0.186	.10486E+03
0.00	0.00	20.90	267.1	0.374E+00	2.84	185.72	0.186	.10640E+03
0.00	0.00	21.18	270.9	0.369E+00	2.88	185.76	0.186	.10794E+03
0.00	0.00	21.47	274.7	0.364E+00	2.92	185.80	0.186	.10948E+03
0.00	0.00	21.76	278.4	0.359E+00	2.96	185.84	0.186	.11101E+03
0.00	0.00	22.04	282.2	0.354E+00	3.00	185.88	0.186	.11255E+03
0.00	0.00	22.33	286.0	0.350E+00	3.04	185.92	0.186	.11409E+03
0.00	0.00	22.61	289.8	0.345E+00	3.08	185.96	0.186	.11562E+03
0.00	0.00	22.90	293.6	0.341E+00	3.12	186.00	0.186	.11716E+03
0.00	0.00	23.19	297.4	0.336E+00	3.17	186.05	0.186	.11870E+03
0.00	0.00	23.47	301.2	0.332E+00	3.21	186.09	0.186	.12024E+03
0.00	0.00	23.76	305.0	0.328E+00	3.25	186.13	0.186	.12177E+03
0.00	0.00	24.04	308.8	0.324E+00	3.29	186.17	0.186	.12331E+03
0.00	0.00	24.33	312.6	0.320E+00	3.33	186.21	0.186	.12484E+03
0.00	0.00	24.62	316.4	0.316E+00	3.37	186.25	0.186	.12638E+03
0.00	0.00	24.90	320.2	0.312E+00	3.41	186.29	0.186	.12792E+03
0.00	0.00	25.19	324.0	0.309E+00	3.45	186.33	0.186	.12946E+03
0.00	0.00	25.47	327.8	0.305E+00	3.49	186.37	0.186	.13099E+03
0.00	0.00	25.76	331.6	0.302E+00	3.53	186.41	0.186	.13253E+03
0.00	0.00	26.05	335.3	0.298E+00	3.57	186.45	0.186	.13407E+03

X	Y	Z	S	C	BV	BH	Uc	TT
0.00	0.00	26.33	339.1	0.295E+00	3.61	186.49	0.186	.13560E+03
0.00	0.00	26.62	342.9	0.292E+00	3.65	186.53	0.186	.13714E+03
0.00	0.00	26.91	346.7	0.288E+00	3.69	186.57	0.186	.13868E+03
0.00	0.00	27.19	350.5	0.285E+00	3.73	186.61	0.186	.14022E+03
X	Y	Z	S	C	BV	BH	Uc	TT
0.00	0.00	27.48	354.3	0.282E+00	3.77	186.65	0.186	.14175E+03
0.00	0.00	27.76	358.1	0.279E+00	3.81	186.69	0.186	.14329E+03
0.00	0.00	28.05	361.9	0.276E+00	3.85	186.73	0.186	.14482E+03
0.00	0.00	28.34	365.7	0.273E+00	3.89	186.77	0.186	.14636E+03
0.00	0.00	28.62	369.5	0.271E+00	3.93	186.81	0.186	.14790E+03
0.00	0.00	28.91	373.3	0.268E+00	3.97	186.85	0.186	.14944E+03
0.00	0.00	29.19	377.1	0.265E+00	4.01	186.89	0.186	.15097E+03
0.00	0.00	29.48	380.9	0.263E+00	4.05	186.93	0.186	.15251E+03

Cumulative travel time = 152.5065 sec (0.04 hrs)

END OF CORJET (MOD110): JET/PLUME NEAR-FIELD MIXING REGION

BEGIN MOD232: LAYER BOUNDARY IMPINGEMENT/UPSTREAM SPREADING

Vertical angle of layer/boundary impingement = 90.00 deg
 Horizontal angle of layer/boundary impingement = 0.00 deg

Discharge into STAGNANT AMBIENT environment:

STEADY-STATE MIXING CONDITION IS NOT POSSIBLE in this zone,
 even though some ADDITIONAL DILUTION MAY OCCUR!
 Also, all far-field processes will be UNSTEADY.

SIMULATION STOPS because of stagnant ambient conditions.

END OF MOD232: LAYER BOUNDARY IMPINGEMENT/UPSTREAM SPREADING


** End of NEAR-FIELD REGION (NFR) **

SIMULATION STOPS because of STAGNANT AMBIENT conditions.
 All far-field processes will be UNSTEADY.

CORMIX2: Multiport Diffuser Discharges End of Prediction File

Initial Dilution Solutions, San Elijo Ocean Outfall (SEOO)

February 2014, maximum discharge (23.25 mgd) with maximum brine additions, CORMIX v-12



THIS PAGE INTENTIONALLY LEFT BLANK

APPENDIX C:

Plumes 20 Initial Dilution Results for Discharge Scenario #2: Maximum Discharge Rate (23.25 mgd) with Maximum Brine Additions based on Spring Density Profiles from March 2014 Through May 2014

C.1 Maximum SEOO Discharge with Maximum Brine Additions for March 2014 Density Profiles

Project "C:\Plumes20\Max-SEOO_Mar2014_Max-Brine"
 memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/21/2022 11:45:38 AM

Case 1; ambient file C:\Plumes20\Max-SEOO_Mar2014_Max-Brine.001.db; Diffuser table record 1

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m0.67/s2	sigma-T
0.0	0.0	0.0	35.71	16.50	0.0	0.0	0.0	0.0	0.0	26.19803
3.048	0.0	0.0	35.70	16.49	0.0	0.0	0.0	0.0	0.0	26.19364
6.096	0.0	0.0	35.61	16.38	0.0	0.0	0.0	0.0	0.0	26.14659
9.143	0.0	0.0	35.63	16.11	0.0	0.0	0.0	0.0	0.0	26.22430
12.19	0.0	0.0	35.66	15.71	0.0	0.0	0.0	0.0	0.0	26.34095
15.24	0.0	0.0	35.49	15.27	0.0	0.0	0.0	0.0	0.0	26.31399
18.29	0.0	0.0	35.38	14.76	0.0	0.0	0.0	0.0	0.0	26.33594
21.33	0.0	0.0	35.26	14.39	0.0	0.0	0.0	0.0	0.0	26.32377
24.38	0.0	0.0	35.20	14.03	0.0	0.0	0.0	0.0	0.0	26.35746
27.43	0.0	0.0	35.17	13.92	0.0	0.0	0.0	0.0	0.0	26.36071
30.48	0.0	0.0	34.91	12.17	0.0	0.0	0.0	0.0	0.0	26.51278
33.53	0.0	0.0	34.89	11.85	0.0	0.0	0.0	0.0	0.0	26.55198
36.57	0.0	0.0	34.89	11.85	0.0	0.0	0.0	0.0	0.0	26.55198
39.62	0.0	0.0	34.90	11.83	0.0	0.0	0.0	0.0	0.0	26.56509
42.67	0.0	0.0	34.90	11.83	0.0	0.0	0.0	0.0	0.0	26.56509

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isopth	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	23.250	1.3400	22.500	1200.0

Simulation:

Froude No: 39.56; Strat No: 1.22E-5; Spcg No: 14.05; k: 4.12E+5; eff den (sigmaT) -1.267032;
 eff vel 4.119(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn ()	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.340	-1.26703	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.656	5.150	1.89597	1.125	0.0359	0.0	0.04207; bottom hit;
15	140.0	0.0	2.292	12.35	7.86058	1.475	0.150	0.0	0.05821;
30	140.0	0.0	3.077	18.15	12.6525	1.976	0.312	0.0	0.07816;
45	140.0	0.0	4.134	22.45	16.2153	2.650	0.531	0.0	0.1050;
60	140.0	0.0	5.556	25.65	18.8662	3.557	0.826	0.0	0.1411;
75	140.0	0.0	7.471	28.03	20.8391	4.778	1.223	0.0	0.1898;
90	140.0	0.0	10.05	29.79	22.3072	6.421	1.759	0.0	0.2552;
105	139.9	0.0	13.50	31.11	23.3994	8.633	2.479	0.0	0.3430;
120	139.9	0.0	18.13	32.08	24.2118	11.61	3.445	0.0	0.4606;
131	139.7	0.0	22.19	32.60	24.6448	14.22	4.288	0.0	0.5636; merging;
135	139.7	0.0	23.48	32.72	24.7480	15.03	4.570	0.0	0.5963;
150	139.5	0.0	27.48	33.04	25.0076	17.54	5.540	0.0	0.6981;
165	139.2	0.0	30.86	33.24	25.1758	19.66	6.424	0.0	0.7838;
180	138.9	0.0	33.88	33.39	25.3014	21.61	7.263	0.0	0.8605;
195	138.5	0.0	36.68	33.51	25.4032	23.51	8.081	0.0	0.9317;
210	138.0	0.0	39.35	33.61	25.4907	25.42	8.896	0.0	0.9994;
225	137.5	0.0	41.95	33.71	25.5690	27.42	9.723	0.0	1.0654;
240	136.8	0.0	44.55	33.80	25.6418	29.58	10.58	0.0	1.1316;
255	136.0	0.0	47.24	33.88	25.7113	31.99	11.47	0.0	1.1999;
270	134.9	0.0	50.12	33.96	25.7795	34.76	12.43	0.0	1.2732;
285	133.7	0.0	53.36	34.04	25.8478	38.07	13.47	0.0	1.3552;
300	132.0	0.0	57.17	34.12	25.9173	42.15	14.61	0.0	1.4520;
315	129.8	0.0	61.92	34.21	25.9892	47.41	15.90	0.0	1.5729;
330	126.8	0.0	68.29	34.30	26.0640	54.52	17.39	0.0	1.7345;
345	122.3	0.0	77.53	34.39	26.1422	64.75	19.17	0.0	1.9692;
360	115.4	0.0	92.19	34.49	26.2231	80.65	21.37	0.0	2.3417;
375	104.0	0.0	117.1	34.59	26.3031	107.0	24.13	0.0	2.9750;
390	87.51	0.0	163.6	34.70	26.3461	144.0	27.15	0.0	4.1561;
399	73.33	0.0	224.8	34.78	26.3503	172.0	29.56	0.0	5.7094; trap level;
405	60.68	0.0	290.4	34.83	26.3501	193.8	31.75	0.0	7.3749;
420	27.80	0.0	647.5	34.95	26.3504	236.9	38.41	0.0	16.448; begin overlap;
435	25.83	0.0	862.3	34.96	26.3501	237.7	39.01	0.0	21.903;
450	24.94	0.0	1056.5	34.96	26.3500	237.8	39.36	0.0	26.835;
465	24.46	0.0	1242.4	34.96	26.3500	237.8	39.60	0.0	31.558;
466	24.43	0.0	1254.5	34.96	26.3500	237.8	39.61	0.0	31.865; surface;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 12.073

Lmz(m): 12.073


forced entrain 1 0.0 35.23 31.87 0.472

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 35.6155

;

11:45:38 AM. amb fills: 4

Plumes 20 (UM3) Initial Dilution Solutions, San Elijo Ocean Outfall (SEOO)
March 2014, maximum discharge (23.25 mgd) with maximum brine additions



C.2 Maximum SEOO Discharge with Maximum Brine Additions for April 2014 Density Profiles

Project "C:\Plumes20\Max-SEOO_Apr2014_Max-Brine"
memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/21/2022 12:16:26 PM

Case 1; ambient file C:\Plumes20\Max-SEOO_Apr2014_Max-Brine.001.db; Diffuser table record 1

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	0.67/s2	sigma-T
0.0	0.0	0.0	34.00	14.61	0.0	0.0	0.0	0.0	0.0	25.30798
3.048	0.0	0.0	33.95	14.62	0.0	0.0	0.0	0.0	0.0	25.26842
6.096	0.0	0.0	33.95	13.84	0.0	0.0	0.0	0.0	0.0	25.43362
9.143	0.0	0.0	33.64	12.78	0.0	0.0	0.0	0.0	0.0	25.40372
12.19	0.0	0.0	33.69	12.64	0.0	0.0	0.0	0.0	0.0	25.47018
15.24	0.0	0.0	33.60	12.01	0.0	0.0	0.0	0.0	0.0	25.52377
18.29	0.0	0.0	33.49	11.63	0.0	0.0	0.0	0.0	0.0	25.51043
21.33	0.0	0.0	33.50	11.44	0.0	0.0	0.0	0.0	0.0	25.55376
24.38	0.0	0.0	33.48	11.32	0.0	0.0	0.0	0.0	0.0	25.55665
27.43	0.0	0.0	33.48	11.27	0.0	0.0	0.0	0.0	0.0	25.56855
30.48	0.0	0.0	33.45	11.23	0.0	0.0	0.0	0.0	0.0	25.54772
33.53	0.0	0.0	33.43	11.21	0.0	0.0	0.0	0.0	0.0	25.54147
36.57	0.0	0.0	33.43	11.21	0.0	0.0	0.0	0.0	0.0	25.54147
39.62	0.0	0.0	33.43	11.19	0.0	0.0	0.0	0.0	0.0	25.54490
42.67	0.0	0.0	33.43	11.19	0.0	0.0	0.0	0.0	0.0	25.54490

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplth	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	23.250	1.3400	22.500	1200.0

Simulation:

Froude No: 40.31; Strat No: 8.22E-6; Spcg No: 14.05; k: 4.12E+5; eff den (sigmaT) -1.267032;
 eff vel 4.119(m/s);

Current is very small, flow regime may be transient.

Step	Depth	Amb-cur	P-dia	Eff-sal	Density	Dilutn	x-posn	y-posn	Iso dia
	(ft)	(m/s)	(in)	(psu)	(sigmaT)	()	(ft)	(ft)	(m)
0	140.0	1.000E-5	1.562	1.340	-1.26703	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.656	4.980	1.78380	1.125	0.0359	0.0	0.04207; bottom hit;
15	140.0	0.0	2.292	11.87	7.53890	1.475	0.150	0.0	0.05821;
30	140.0	0.0	3.077	17.41	12.1584	1.976	0.312	0.0	0.07817;
45	140.0	0.0	4.135	21.53	15.5902	2.651	0.531	0.0	0.1050;
60	140.0	0.0	5.558	24.59	18.1422	3.559	0.826	0.0	0.1412;
75	140.0	0.0	7.473	26.86	20.0404	4.781	1.224	0.0	0.1898;
90	140.0	0.0	10.05	28.55	21.4524	6.426	1.760	0.0	0.2552;
105	139.9	0.0	13.51	29.80	22.5026	8.639	2.480	0.0	0.3432;
120	139.9	0.0	18.14	30.74	23.2835	11.62	3.447	0.0	0.4609;
131	139.8	0.0	22.28	31.24	23.7063	14.29	4.307	0.0	0.5659; merging;
135	139.7	0.0	23.61	31.36	23.8072	15.12	4.599	0.0	0.5996;
150	139.5	0.0	27.73	31.66	24.0594	17.68	5.599	0.0	0.7044;
165	139.2	0.0	31.20	31.86	24.2215	19.85	6.509	0.0	0.7925;
180	138.9	0.0	34.30	32.00	24.3420	21.83	7.371	0.0	0.8713;
195	138.5	0.0	37.18	32.12	24.4393	23.75	8.210	0.0	0.9444;
210	138.0	0.0	39.92	32.22	24.5227	25.69	9.044	0.0	1.0139;
225	137.4	0.0	42.58	32.30	24.5972	27.71	9.891	0.0	1.0816;
240	136.8	0.0	45.25	32.39	24.6663	29.89	10.76	0.0	1.1494;
255	135.9	0.0	48.00	32.46	24.7322	32.31	11.68	0.0	1.2192;
270	134.9	0.0	50.94	32.54	24.7968	35.10	12.65	0.0	1.2940;
285	133.6	0.0	54.23	32.62	24.8613	38.41	13.71	0.0	1.3775;
300	131.9	0.0	58.10	32.70	24.9270	42.49	14.88	0.0	1.4757;
315	129.7	0.0	62.91	32.78	24.9948	47.73	16.19	0.0	1.5979;
330	126.7	0.0	69.30	32.86	25.0655	54.78	17.70	0.0	1.7601;
345	122.3	0.0	78.42	32.95	25.1396	64.82	19.49	0.0	1.9919;
360	115.5	0.0	92.63	33.04	25.2169	80.25	21.68	0.0	2.3528;
375	104.2	0.0	116.8	33.14	25.2957	105.9	24.45	0.0	2.9655;
390	88.24	0.0	151.1	33.22	25.3620	142.6	27.32	0.0	3.8374;
405	67.08	0.0	197.8	33.29	25.4126	191.9	30.08	0.0	5.0232;
420	38.04	0.0	277.0	33.36	25.4400	258.2	32.97	0.0	7.0370;
424	28.26	0.0	313.8	33.38	25.4412	279.5	33.84	0.0	7.9702; trap level;
430	10.19	0.0	410.6	33.43	25.4400	314.8	35.52	0.0	10.428; matched energy
434	2.460	0.0	553.7	33.45	25.4360	327.8	36.38	0.0	14.065; surface;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 11.088


Lmz(m): 11.088

forced entrain 1 0.0 41.92 14.06 0.117

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 33.9825

;

12:16:27 PM. amb fills: 4



C.3 Maximum SEOO Discharge with Maximum Brine Additions for May 2014 Density Profiles

Project "C:\Plumes20\Max-SEOO_May2014_Max-Brine"

memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/21/2022 12:48:43 PM

Case 1; ambient file C:\Plumes20\Max-SEOO_May2014_Max-Brine.001.db; Diffuser table record 1

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m 0.67/s2	sigma-T
0.0	0.0	0.0	33.47	17.00	0.0	0.0	0.0	0.0	0.0	24.36431
3.048	0.0	0.0	33.46	16.99	0.0	0.0	0.0	0.0	0.0	24.35984
6.096	0.0	0.0	33.48	16.95	0.0	0.0	0.0	0.0	0.0	24.37988
9.143	0.0	0.0	33.48	16.81	0.0	0.0	0.0	0.0	0.0	24.41370
12.19	0.0	0.0	33.40	16.39	0.0	0.0	0.0	0.0	0.0	24.45040
15.24	0.0	0.0	33.16	14.81	0.0	0.0	0.0	0.0	0.0	24.61622
18.29	0.0	0.0	32.80	13.21	0.0	0.0	0.0	0.0	0.0	24.67571
21.33	0.0	0.0	32.68	12.41	0.0	0.0	0.0	0.0	0.0	24.73594
24.38	0.0	0.0	32.57	12.05	0.0	0.0	0.0	0.0	0.0	24.71709
27.43	0.0	0.0	32.55	11.88	0.0	0.0	0.0	0.0	0.0	24.73096
30.48	0.0	0.0	32.49	11.88	0.0	0.0	0.0	0.0	0.0	24.68818
33.53	0.0	0.0	32.48	11.79	0.0	0.0	0.0	0.0	0.0	24.69958
36.57	0.0	0.0	32.48	11.79	0.0	0.0	0.0	0.0	0.0	24.69958
39.62	0.0	0.0	32.50	11.78	0.0	0.0	0.0	0.0	0.0	24.71514
42.67	0.0	0.0	32.50	11.78	0.0	0.0	0.0	0.0	0.0	24.71514

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	23.250	1.3400	22.500	1200.0

Simulation:

Froude No: 40.94; Strat No: 1.25E-5; Spcg No: 14.05; k: 4.12E+5; eff den (sigmaT) -1.267032;
 eff vel 4.119(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn (%)	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.340	-1.26703	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.656	4.872	1.68653	1.125	0.036	0.0	0.04207; bottom hit;
15	140.0	0.0	2.292	11.56	7.26396	1.476	0.150	0.0	0.05821;
30	140.0	0.0	3.078	16.94	11.7416	1.977	0.312	0.0	0.07818;
45	140.0	0.0	4.135	20.94	15.0681	2.652	0.531	0.0	0.1050;
60	140.0	0.0	5.559	23.91	17.5415	3.561	0.827	0.0	0.1412;
75	140.0	0.0	7.475	26.12	19.3813	4.784	1.225	0.0	0.1899;
90	140.0	0.0	10.05	27.76	20.7497	6.430	1.760	0.0	0.2553;
105	139.9	0.0	13.51	28.98	21.7674	8.645	2.481	0.0	0.3433;
120	139.9	0.0	18.15	29.88	22.5241	11.63	3.449	0.0	0.4611;
130	139.8	0.0	21.97	30.34	22.9078	14.09	4.244	0.0	0.5581; merging;
135	139.7	0.0	23.70	30.50	23.0370	15.18	4.621	0.0	0.6020;
150	139.5	0.0	27.92	30.79	23.2839	17.79	5.646	0.0	0.7093;
165	139.2	0.0	31.47	30.98	23.4415	19.99	6.577	0.0	0.7993;
180	138.9	0.0	34.64	31.12	23.5581	22.01	7.457	0.0	0.8799;
195	138.5	0.0	37.58	31.23	23.6520	23.95	8.313	0.0	0.9545;
210	138.0	0.0	40.37	31.33	23.7323	25.90	9.164	0.0	1.0255;
225	137.4	0.0	43.09	31.41	23.8039	27.94	10.03	0.0	1.0946;
240	136.7	0.0	45.81	31.49	23.8702	30.13	10.91	0.0	1.1636;
255	135.9	0.0	48.61	31.57	23.9335	32.57	11.85	0.0	1.2347;
270	134.9	0.0	51.60	31.64	23.9953	35.36	12.84	0.0	1.3107;
285	133.5	0.0	54.94	31.71	24.0570	38.68	13.91	0.0	1.3954;
300	131.9	0.0	58.85	31.79	24.1199	42.76	15.09	0.0	1.4947;
315	129.6	0.0	63.70	31.87	24.1847	47.99	16.42	0.0	1.6180;
330	126.6	0.0	70.16	31.95	24.2522	55.02	17.95	0.0	1.7822;
345	122.1	0.0	79.51	32.03	24.3225	65.08	19.78	0.0	2.0196;
360	115.2	0.0	94.25	32.12	24.3953	80.59	22.04	0.0	2.3940;
375	103.8	0.0	119.1	32.21	24.4685	106.3	24.90	0.0	3.0258;
390	87.37	0.0	155.1	32.28	24.5292	143.0	27.92	0.0	3.9401;
405	65.77	0.0	200.2	32.37	24.5798	192.5	30.78	0.0	5.0845;
417	43.13	0.0	268.0	32.48	24.6002	244.1	33.13	0.0	6.8081; trap level;
420	36.05	0.0	309.0	32.53	24.5983	259.0	33.87	0.0	7.8475;
435	23.90	0.0	659.6	32.60	24.5921	277.9	35.58	0.0	16.754;
436	23.65	0.0	680.2	32.60	24.5920	278.1	35.64	0.0	17.277; begin overlap;
450	21.57	0.0	951.1	32.60	24.5916	279.1	36.12	0.0	24.159;
465	20.66	0.0	1225.4	32.60	24.5916	279.2	36.41	0.0	31.125;
471	20.45	0.0	1332.2	32.60	24.5915	279.2	36.49	0.0	33.838; surface;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 11.124

Lmz(m): 11.124


forced entrain 1 0.0 36.44 33.84 0.366

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 33.4751

;

12:48:43 PM. amb fills: 4

Plumes 20 (UM3) Initial Dilution Solutions, San Elijo Ocean Outfall (SEOO)
May 2014, maximum discharge (23.25 mgd) with maximum brine additions



APPENDIX D:

Plumes 20 Initial Dilution Results for Discharge Scenario #3: Minimum Discharge Rate (7.2 mgd) with Maximum Brine Additions based on Summer Density Profiles from June 2014 Through August 2014

D.1 Minimum SEOO Discharge with Maximum Brine Additions for June 2014 Density Profiles

Project "C:\Plumes20\Min-SEOO_June2014_Max-Brine"
memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/21/2022 1:27:30 PM

Case 1; ambient file C:\Plumes20\Max-SEOO_June2014_Max-Brine.001.db; Diffuser table record 1:

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m0.67/s2	sigma-T
0.0	0.0	0.0	33.42	19.73	0.0	0.0	0.0	0.0	0.0	23.65286
3.048	0.0	0.0	33.41	19.73	0.0	0.0	0.0	0.0	0.0	23.64577
6.096	0.0	0.0	33.45	18.72	0.0	0.0	0.0	0.0	0.0	23.93411
9.143	0.0	0.0	33.15	17.43	0.0	0.0	0.0	0.0	0.0	24.01715
12.19	0.0	0.0	32.98	16.61	0.0	0.0	0.0	0.0	0.0	24.07776
15.24	0.0	0.0	32.85	15.39	0.0	0.0	0.0	0.0	0.0	24.25736
18.29	0.0	0.0	32.51	14.30	0.0	0.0	0.0	0.0	0.0	24.22215
21.33	0.0	0.0	32.36	13.73	0.0	0.0	0.0	0.0	0.0	24.22474
24.38	0.0	0.0	32.16	12.84	0.0	0.0	0.0	0.0	0.0	24.25389
27.43	0.0	0.0	32.01	12.40	0.0	0.0	0.0	0.0	0.0	24.21632
30.48	0.0	0.0	31.91	11.91	0.0	0.0	0.0	0.0	0.0	24.23399
33.53	0.0	0.0	31.85	11.46	0.0	0.0	0.0	0.0	0.0	24.26940
36.57	0.0	0.0	31.85	11.46	0.0	0.0	0.0	0.0	0.0	24.26940
39.62	0.0	0.0	31.80	11.44	0.0	0.0	0.0	0.0	0.0	24.23334
42.67	0.0	0.0	31.80	11.44	0.0	0.0	0.0	0.0	0.0	24.23334

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	7.2000	1.8800	22.500	1200.0

Simulation:

Froude No: 12.91; Strat No: 2.15E-5; Spcg No: 14.05; k: 1.27E+5; eff den (sigmaT) -0.858500;
 eff vel 1.276(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn (%)	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.880	-0.858500	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.592	3.018	0.10105	1.039	0.0121	0.0	0.04043; bottom hit;
15	140.0	0.0	2.114	9.987	5.95736	1.362	0.117	0.0	0.0537;
30	140.0	0.0	2.839	15.59	10.6528	1.825	0.267	0.0	0.0721;
45	140.0	0.0	3.813	19.76	14.1379	2.448	0.468	0.0	0.09685;
60	140.0	0.0	5.121	22.85	16.7278	3.286	0.740	0.0	0.1301;
75	139.9	0.0	6.845	25.13	18.6336	4.399	1.099	0.0	0.1739;
90	139.9	0.0	8.465	26.43	19.7217	5.456	1.436	0.0	0.2150;
105	139.8	0.0	9.832	27.21	20.3800	6.385	1.726	0.0	0.2497;
120	139.7	0.0	11.05	27.76	20.8433	7.256	1.990	0.0	0.2806;
135	139.6	0.0	12.16	28.19	21.2003	8.108	2.237	0.0	0.3089;
150	139.5	0.0	13.21	28.54	21.4933	8.974	2.475	0.0	0.3356;
165	139.3	0.0	14.23	28.84	21.7451	9.881	2.709	0.0	0.3614;
180	139.2	0.0	15.23	29.11	21.9698	10.86	2.945	0.0	0.3868;
195	139.0	0.0	16.25	29.35	22.1763	11.95	3.185	0.0	0.4127;
210	138.7	0.0	17.31	29.58	22.3712	13.20	3.433	0.0	0.4398;
225	138.4	0.0	18.47	29.81	22.5589	14.68	3.695	0.0	0.4691;
240	138.1	0.0	19.77	30.03	22.7431	16.49	3.975	0.0	0.5020;
255	137.6	0.0	21.29	30.25	22.9265	18.80	4.279	0.0	0.5409;
261	137.4	0.0	22.00	30.33	23.0000	19.92	4.410	0.0	0.5587; merging;
270	137.0	0.0	23.07	30.46	23.1039	21.75	4.618	0.0	0.5860;
285	136.1	0.0	25.10	30.66	23.2717	25.54	5.006	0.0	0.6376;
300	134.8	0.0	27.82	30.86	23.4413	31.01	5.468	0.0	0.7065;
315	132.8	0.0	31.92	31.07	23.6157	39.76	6.042	0.0	0.8107;
330	129.8	0.0	38.07	31.25	23.7741	53.47	6.702	0.0	0.9669;
345	125.7	0.0	46.04	31.40	23.8938	71.96	7.341	0.0	1.1694;
360	120.4	0.0	56.33	31.51	23.9870	96.84	7.959	0.0	1.4308;
375	113.5	0.0	69.96	31.60	24.0595	130.3	8.553	0.0	1.7769;
390	104.4	0.0	89.16	31.66	24.1124	175.4	9.134	0.0	2.2646;
405	92.09	0.0	119.8	31.73	24.1443	236.0	9.736	0.0	3.0440;
420	74.86	0.0	160.9	31.82	24.1686	317.7	10.39	0.0	4.0876;
435	51.52	0.0	221.7	31.98	24.1892	427.5	11.06	0.0	5.6308;
440	41.95	0.0	242.3	32.06	24.1973	472.0	11.29	0.0	6.1554; trap level;
449	29.08	0.0	713.6	32.15	24.1934	524.3	11.74	0.0	18.125; begin overlap;
450	28.91	0.0	802.9	32.15	24.1934	524.4	11.75	0.0	20.393;
465	28.23	0.0	1916.5	32.15	24.1934	524.6	11.82	0.0	48.679;
480	28.12	0.0	2932.8	32.15	24.1934	524.6	11.84	0.0	74.493; surface;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 3.6102


Lmz(m): 3.6102

forced entrain 1 0.0 34.10 74.49 0.231

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 33.2068

;

1:27:30 PM. amb fills: 4



D.2 Minimum SEOO Discharge with Maximum Brine Additions for July 2014 Density Profiles

Project "C:\Plumes20\Min-SEOO_July2014_Max-Brine"
 memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/21/2022 2:10:43 PM

Case 1; ambient file C:\Plumes20\Max-SEOO_July2014_Max-Brine.001.db; Diffuser table record 1:

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m 0.67/s ²	sigma-T
0.0	0.0	0.0	33.95	21.92	0.0	0.0	0.0	0.0	0.0	23.46816
3.048	0.0	0.0	33.94	21.90	0.0	0.0	0.0	0.0	0.0	23.46917
6.096	0.0	0.0	34.01	21.84	0.0	0.0	0.0	0.0	0.0	23.53555
9.143	0.0	0.0	34.02	19.27	0.0	0.0	0.0	0.0	0.0	24.22836
12.19	0.0	0.0	32.77	15.12	0.0	0.0	0.0	0.0	0.0	24.25294
15.24	0.0	0.0	32.45	14.32	0.0	0.0	0.0	0.0	0.0	24.17258
18.29	0.0	0.0	32.38	13.85	0.0	0.0	0.0	0.0	0.0	24.22064
21.33	0.0	0.0	32.23	13.14	0.0	0.0	0.0	0.0	0.0	24.24290
24.38	0.0	0.0	32.20	13.00	0.0	0.0	0.0	0.0	0.0	24.25090
27.43	0.0	0.0	32.16	12.83	0.0	0.0	0.0	0.0	0.0	24.25563
30.48	0.0	0.0	32.14	12.63	0.0	0.0	0.0	0.0	0.0	24.27779
33.53	0.0	0.0	32.15	12.50	0.0	0.0	0.0	0.0	0.0	24.30805
36.57	0.0	0.0	32.15	12.50	0.0	0.0	0.0	0.0	0.0	24.30805
39.62	0.0	0.0	32.15	12.48	0.0	0.0	0.0	0.0	0.0	24.31244
42.67	0.0	0.0	32.15	12.48	0.0	0.0	0.0	0.0	0.0	24.31244

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	7.2000	1.8800	22.500	1200.0

Simulation:

Froude No: 12.88; Strat No: 3.12E-5; Spcg No: 14.05; k: 1.27E+5; eff den (sigmaT) -0.858500;
 eff vel 1.276(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn (%)	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.880	-0.858500	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.592	3.032	0.10200	1.039	0.0121	0.0	0.04043; bottom hit;
15	140.0	0.0	2.114	10.08	5.96740	1.362	0.117	0.0	0.0537;
30	140.0	0.0	2.839	15.75	10.6748	1.825	0.267	0.0	0.0721;
45	140.0	0.0	3.813	19.97	14.1715	2.448	0.468	0.0	0.09685;
60	140.0	0.0	5.120	23.10	16.7714	3.286	0.740	0.0	0.1301;
75	139.9	0.0	6.844	25.40	18.6839	4.397	1.099	0.0	0.1738;
90	139.9	0.0	8.457	26.71	19.7740	5.450	1.434	0.0	0.2148;
105	139.8	0.0	9.818	27.50	20.4347	6.377	1.723	0.0	0.2494;
120	139.7	0.0	11.03	28.06	20.9001	7.245	1.986	0.0	0.2801;
135	139.6	0.0	12.14	28.49	21.2591	8.095	2.232	0.0	0.3083;
150	139.5	0.0	13.19	28.84	21.5537	8.958	2.470	0.0	0.3350;
165	139.3	0.0	14.20	29.15	21.8071	9.863	2.704	0.0	0.3607;
180	139.2	0.0	15.20	29.42	22.0332	10.84	2.938	0.0	0.3861;
195	139.0	0.0	16.22	29.67	22.2412	11.93	3.178	0.0	0.4119;
210	138.7	0.0	17.28	29.90	22.4373	13.17	3.426	0.0	0.4389;
225	138.4	0.0	18.43	30.13	22.6264	14.65	3.687	0.0	0.4681;
240	138.1	0.0	19.73	30.35	22.8120	16.46	3.966	0.0	0.5010;
255	137.6	0.0	21.25	30.57	22.9967	18.77	4.270	0.0	0.5398;
261	137.4	0.0	21.95	30.66	23.0708	19.89	4.400	0.0	0.5576; merging;
270	137.0	0.0	23.03	30.79	23.1759	21.73	4.608	0.0	0.5851;
285	136.1	0.0	25.07	30.99	23.3451	25.53	4.995	0.0	0.6367;
300	134.9	0.0	27.78	31.20	23.5159	31.00	5.457	0.0	0.7056;
315	132.8	0.0	31.89	31.41	23.6916	39.77	6.030	0.0	0.8099;
330	129.8	0.0	38.03	31.60	23.8509	53.48	6.687	0.0	0.9659;
345	125.7	0.0	46.09	31.74	23.9693	71.98	7.325	0.0	1.1707;
360	120.4	0.0	56.87	31.84	24.0567	96.86	7.952	0.0	1.4445;
375	113.3	0.0	71.52	31.92	24.1213	130.4	8.572	0.0	1.8166;
390	104.0	0.0	91.85	31.98	24.1682	175.4	9.191	0.0	2.3330;
405	91.20	0.0	124.2	32.02	24.1960	236.1	9.839	0.0	3.1547;
420	72.95	0.0	176.4	32.06	24.2108	317.8	10.58	0.0	4.4812;
431	54.36	0.0	238.0	32.11	24.2158	395.1	11.22	0.0	6.0445; trap level;
435	45.75	0.0	286.6	32.13	24.2144	427.7	11.53	0.0	7.2784;
438	37.41	0.0	349.8	32.16	24.2150	453.8	11.84	0.0	8.8844; trap level;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 3.6101


Lmz(m): 3.6101

forced entrain 1 0.0 31.27 8.884 0.0386

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 32.7560

;

2:10:44 PM. amb fills: 4



D.3 Minimum SEOO Discharge with Maximum Brine Additions for August 2014 Density Profiles

Project "C:\Plumes20\Min-SEOO_Aug2014_Max-Brine"
 memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/21/2022 2:35:01 PM

Case 1; ambient file C:\Plumes20\Max-SEOO_Aug2014_Max-Brine.001.db; Diffuser table record 1

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m 0.67/s2	sigma-T
0.0	0.0	0.0	34.00	22.46	0.0	0.0	0.0	0.0	0.0	23.35347
3.048	0.0	0.0	34.00	22.46	0.0	0.0	0.0	0.0	0.0	23.35432
6.096	0.0	0.0	33.80	20.82	0.0	0.0	0.0	0.0	0.0	23.65416
9.143	0.0	0.0	33.53	19.86	0.0	0.0	0.0	0.0	0.0	23.70283
12.19	0.0	0.0	33.09	18.58	0.0	0.0	0.0	0.0	0.0	23.69328
15.24	0.0	0.0	32.91	16.52	0.0	0.0	0.0	0.0	0.0	24.04382
18.29	0.0	0.0	32.41	15.48	0.0	0.0	0.0	0.0	0.0	23.90214
21.33	0.0	0.0	32.44	15.40	0.0	0.0	0.0	0.0	0.0	23.93447
24.38	0.0	0.0	32.36	14.40	0.0	0.0	0.0	0.0	0.0	24.09144
27.43	0.0	0.0	32.19	13.79	0.0	0.0	0.0	0.0	0.0	24.08669
30.48	0.0	0.0	32.04	13.45	0.0	0.0	0.0	0.0	0.0	24.03956
33.53	0.0	0.0	31.93	12.88	0.0	0.0	0.0	0.0	0.0	24.06816
36.57	0.0	0.0	31.93	12.88	0.0	0.0	0.0	0.0	0.0	24.06816
39.62	0.0	0.0	31.93	12.88	0.0	0.0	0.0	0.0	0.0	24.06913
42.67	0.0	0.0	31.93	12.88	0.0	0.0	0.0	0.0	0.0	24.06913

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	7.2000	1.8800	22.500	1200.0

Simulation:

Froude No: 12.95; Strat No: 2.67E-5; Spcg No: 14.05; k: 1.27E+5; eff den (sigmaT) -0.858500;
 eff vel 1.276(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn (%)	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.880	-0.858500	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.592	3.023	0.092036	1.039	0.0121	0.0	0.04043; bottom hit;
15	140.0	0.0	2.114	10.02	5.89895	1.362	0.117	0.0	0.0537;
30	140.0	0.0	2.839	15.65	10.5605	1.825	0.267	0.0	0.07211;
45	140.0	0.0	3.813	19.84	14.0237	2.448	0.468	0.0	0.09686;
60	140.0	0.0	5.121	22.95	16.5990	3.286	0.740	0.0	0.1301;
75	139.9	0.0	6.847	25.23	18.4960	4.400	1.099	0.0	0.1739;
90	139.9	0.0	8.473	26.54	19.5812	5.461	1.438	0.0	0.2152;
105	139.8	0.0	9.844	27.33	20.2369	6.393	1.729	0.0	0.2500;
120	139.7	0.0	11.06	27.88	20.6980	7.266	1.993	0.0	0.2810;
135	139.6	0.0	12.18	28.31	21.0533	8.120	2.241	0.0	0.3094;
150	139.5	0.0	13.23	28.66	21.3446	8.987	2.479	0.0	0.3361;
165	139.3	0.0	14.25	28.96	21.5950	9.896	2.714	0.0	0.3619;
180	139.2	0.0	15.25	29.23	21.8183	10.88	2.950	0.0	0.3875;
195	139.0	0.0	16.28	29.48	22.0236	11.97	3.190	0.0	0.4134;
210	138.7	0.0	17.34	29.71	22.2172	13.22	3.439	0.0	0.4405;
225	138.4	0.0	18.50	29.93	22.4038	14.70	3.701	0.0	0.4698;
240	138.1	0.0	19.80	30.15	22.5868	16.51	3.982	0.0	0.5028;
255	137.6	0.0	21.33	30.37	22.7689	18.82	4.287	0.0	0.5417;
261	137.4	0.0	22.03	30.46	22.8420	19.94	4.418	0.0	0.5595; merging;
270	137.0	0.0	23.10	30.58	22.9450	21.77	4.626	0.0	0.5867;
285	136.1	0.0	25.13	30.78	23.1117	25.55	5.014	0.0	0.6382;
300	134.8	0.0	27.84	30.99	23.2802	31.01	5.477	0.0	0.7071;
315	132.8	0.0	31.93	31.19	23.4535	39.74	6.052	0.0	0.8111;
330	129.8	0.0	38.08	31.38	23.6114	53.44	6.712	0.0	0.9673;
345	125.7	0.0	46.15	31.53	23.7289	71.91	7.355	0.0	1.1722;
360	120.4	0.0	56.91	31.63	23.8162	96.78	7.984	0.0	1.4455;
375	113.3	0.0	71.49	31.71	23.8809	130.2	8.606	0.0	1.8160;
390	104.0	0.0	91.74	31.77	23.9281	175.3	9.225	0.0	2.3303;
405	91.26	0.0	121.5	31.84	23.9605	235.9	9.864	0.0	3.0854;
420	74.69	0.0	152.5	31.96	23.9932	317.5	10.47	0.0	3.8744;
423	70.81	0.0	164.9	31.98	23.9948	336.9	10.59	0.0	4.1888; trap level;
435	46.84	0.0	403.2	32.08	23.9870	423.6	11.61	0.0	10.241; trap level;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 3.5376


Lmz(m): 3.5376

forced entrain 1 0.0 28.40 10.24 0.0528

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 32.8816

;

2:35:01 PM. amb fills: 4



APPENDIX E:

Plumes 20 Initial Dilution Results for Discharge Scenario #4: Minimum Discharge Rate (7.2 mgd) with Maximum Brine Additions based on Autumn Density Profiles from September 2014 Through November 2014

E.1 Minimum SEOO Discharge with Maximum Brine Additions for September 2014 Density Profiles

Project "C:\Plumes20\Min-SEOO_Sept2014_Max-Brine"
memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/22/2022 9:57:10 AM

Case 1; ambient file C:\Plumes20\Max-SEOO_Sept2014_Max-Brine.001.db; Diffuser table record 1:

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m0.67/s2	sigma-T
0.0	0.0	0.0	34.00	21.44	0.0	0.0	0.0	0.0	0.0	23.63623
3.048	0.0	0.0	33.97	21.44	0.0	0.0	0.0	0.0	0.0	23.61815
6.096	0.0	0.0	33.88	19.42	0.0	0.0	0.0	0.0	0.0	24.08204
9.143	0.0	0.0	33.53	17.25	0.0	0.0	0.0	0.0	0.0	24.35451
12.19	0.0	0.0	33.05	16.55	0.0	0.0	0.0	0.0	0.0	24.14732
15.24	0.0	0.0	33.06	16.11	0.0	0.0	0.0	0.0	0.0	24.25544
18.29	0.0	0.0	32.92	15.90	0.0	0.0	0.0	0.0	0.0	24.20016
21.33	0.0	0.0	32.84	15.76	0.0	0.0	0.0	0.0	0.0	24.16109
24.38	0.0	0.0	32.88	15.40	0.0	0.0	0.0	0.0	0.0	24.27863
27.43	0.0	0.0	32.68	14.81	0.0	0.0	0.0	0.0	0.0	24.24765
30.48	0.0	0.0	32.45	14.50	0.0	0.0	0.0	0.0	0.0	24.14262
33.53	0.0	0.0	32.46	14.22	0.0	0.0	0.0	0.0	0.0	24.20605
36.57	0.0	0.0	32.46	14.22	0.0	0.0	0.0	0.0	0.0	24.20605
39.62	0.0	0.0	32.50	14.17	0.0	0.0	0.0	0.0	0.0	24.24721
42.67	0.0	0.0	32.50	14.17	0.0	0.0	0.0	0.0	0.0	24.24721

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	7.2000	1.8800	22.500	1200.0

Simulation:

Froude No: 12.90; Strat No: 2.26E-5; Spcg No: 14.05; k: 1.27E+5; eff den (sigmaT) -0.858500;
 eff vel 1.276(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn (%)	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.880	-0.858500	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.592	3.045	0.097028	1.039	0.0121	0.0	0.04043; bottom hit;
15	140.0	0.0	2.114	10.18	5.93677	1.362	0.117	0.0	0.0537;
30	140.0	0.0	2.839	15.91	10.6290	1.825	0.267	0.0	0.07211;
45	140.0	0.0	3.813	20.18	14.1174	2.448	0.468	0.0	0.09685;
60	140.0	0.0	5.121	23.34	16.7128	3.286	0.740	0.0	0.1301;
75	139.9	0.0	6.844	25.67	18.6229	4.398	1.099	0.0	0.1738;
90	139.9	0.0	8.458	27.00	19.7121	5.451	1.435	0.0	0.2148;
105	139.8	0.0	9.820	27.80	20.3722	6.378	1.724	0.0	0.2494;
120	139.7	0.0	11.03	28.36	20.8372	7.246	1.986	0.0	0.2802;
135	139.6	0.0	12.14	28.80	21.1958	8.096	2.233	0.0	0.3084;
150	139.5	0.0	13.19	29.16	21.4901	8.960	2.470	0.0	0.3350;
165	139.3	0.0	14.20	29.46	21.7433	9.865	2.704	0.0	0.3607;
180	139.2	0.0	15.20	29.74	21.9692	10.84	2.939	0.0	0.3861;
195	139.0	0.0	16.22	29.99	22.1770	11.93	3.178	0.0	0.4119;
210	138.7	0.0	17.28	30.23	22.3730	13.18	3.426	0.0	0.4389;
225	138.4	0.0	18.43	30.46	22.5619	14.65	3.687	0.0	0.4682;
240	138.1	0.0	19.73	30.68	22.7473	16.46	3.967	0.0	0.5011;
255	137.6	0.0	21.25	30.91	22.9319	18.77	4.271	0.0	0.5398;
261	137.4	0.0	21.95	31.00	23.0060	19.89	4.401	0.0	0.5577; merging;
270	137.0	0.0	23.04	31.12	23.1110	21.73	4.608	0.0	0.5851;
285	136.1	0.0	25.07	31.33	23.2800	25.52	4.996	0.0	0.6367;
300	134.9	0.0	27.78	31.54	23.4508	30.99	5.457	0.0	0.7056;
315	132.8	0.0	31.88	31.75	23.6263	39.75	6.030	0.0	0.8098;
330	129.8	0.0	38.02	31.94	23.7856	53.47	6.687	0.0	0.9658;
345	125.7	0.0	46.17	32.08	23.9022	71.95	7.327	0.0	1.1728;
360	120.3	0.0	57.44	32.18	23.9841	96.83	7.964	0.0	1.4590;
375	113.2	0.0	73.18	32.25	24.0412	130.3	8.614	0.0	1.8587;
390	103.5	0.0	95.28	32.31	24.0810	175.4	9.277	0.0	2.4202;
405	89.90	0.0	129.4	32.36	24.1057	236.0	10.01	0.0	3.2876;
420	73.11	0.0	148.8	32.47	24.1455	317.7	10.63	0.0	3.7800;
435	50.45	0.0	218.2	32.58	24.1596	427.5	11.26	0.0	5.5428;
442	37.32	0.0	241.5	32.64	24.1677	491.1	11.56	0.0	6.1351; trap level;
444	33.10	0.0	259.6	32.66	24.1688	510.9	11.65	0.0	6.5945; trap level;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 3.5508

Lmz(m): 3.5508


forced entrain 1 0.0 32.58 6.594 0.022

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 33.2790

;

9:57:10 AM. amb fills: 4

Plumes 20 (UM3) Initial Dilution Solutions, San Elijo Ocean Outfall (SEOO)
September 2014, minimum discharge (7.2 mgd) with maximum brine additions



E.2 Minimum SEOO Discharge with Maximum Brine Additions for October 2014 Density Profiles

Project "C:\Plumes20\Min-SEOO_Oct2014_Max-Brine"
memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/22/2022 10:43:12 AM

Case 1; ambient file C:\Plumes20\Min-SEOO_Oct2014_Max-Brine.001.db; Diffuser table record 1

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m0.67/s2	sigma-T
0.0	0.0	0.0	33.50	21.28	0.0	0.0	0.0	0.0	0.0	23.30255
3.048	0.0	0.0	33.52	21.29	0.0	0.0	0.0	0.0	0.0	23.31322
6.096	0.0	0.0	33.50	21.28	0.0	0.0	0.0	0.0	0.0	23.30104
9.143	0.0	0.0	33.47	21.15	0.0	0.0	0.0	0.0	0.0	23.31202
12.19	0.0	0.0	33.46	20.89	0.0	0.0	0.0	0.0	0.0	23.37808
15.24	0.0	0.0	33.43	20.55	0.0	0.0	0.0	0.0	0.0	23.44574
18.29	0.0	0.0	33.27	19.80	0.0	0.0	0.0	0.0	0.0	23.51859
21.33	0.0	0.0	33.05	19.31	0.0	0.0	0.0	0.0	0.0	23.47883
24.38	0.0	0.0	32.99	18.56	0.0	0.0	0.0	0.0	0.0	23.62385
27.43	0.0	0.0	32.86	18.06	0.0	0.0	0.0	0.0	0.0	23.64193
30.48	0.0	0.0	32.81	17.54	0.0	0.0	0.0	0.0	0.0	23.72833
33.53	0.0	0.0	32.65	16.72	0.0	0.0	0.0	0.0	0.0	23.79972
36.57	0.0	0.0	32.65	16.72	0.0	0.0	0.0	0.0	0.0	23.79972
39.62	0.0	0.0	32.65	16.72	0.0	0.0	0.0	0.0	0.0	23.80171
42.67	0.0	0.0	32.65	16.72	0.0	0.0	0.0	0.0	0.0	23.80171

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isoplh	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	7.2000	1.8800	22.500	1200.0

Simulation:

Froude No: 13.02; Strat No: 1.88E-5; Spcg No: 14.05; k: 1.27E+5; eff den (sigmaT) -0.858500;
 eff vel 1.276(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn (%)	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.880	-0.858500	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.592	3.050	0.078147	1.039	0.0121	0.0	0.04043; bottom hit;
15	140.0	0.0	2.114	10.22	5.80798	1.363	0.117	0.0	0.05371;
30	140.0	0.0	2.839	15.98	10.4155	1.825	0.267	0.0	0.07211;
45	140.0	0.0	3.814	20.27	13.8428	2.449	0.469	0.0	0.09687;
60	140.0	0.0	5.122	23.45	16.3936	3.287	0.740	0.0	0.1301;
75	139.9	0.0	6.851	25.79	18.2758	4.403	1.100	0.0	0.1740;
90	139.9	0.0	8.488	27.14	19.3563	5.470	1.441	0.0	0.2156;
105	139.8	0.0	9.867	27.95	20.0074	6.407	1.733	0.0	0.2506;
120	139.7	0.0	11.09	28.51	20.4647	7.284	1.999	0.0	0.2817;
135	139.6	0.0	12.21	28.95	20.8167	8.142	2.248	0.0	0.3102;
150	139.5	0.0	13.27	29.31	21.1051	9.012	2.487	0.0	0.3371;
165	139.3	0.0	14.29	29.62	21.3530	9.923	2.723	0.0	0.3630;
180	139.2	0.0	15.30	29.89	21.5739	10.91	2.960	0.0	0.3886;
195	139.0	0.0	16.32	30.14	21.7770	12.00	3.201	0.0	0.4146;
210	138.7	0.0	17.39	30.38	21.9684	13.25	3.451	0.0	0.4418;
225	138.4	0.0	18.55	30.61	22.1529	14.73	3.714	0.0	0.4712;
240	138.1	0.0	19.85	30.83	22.3338	16.55	3.995	0.0	0.5043;
255	137.6	0.0	21.38	31.06	22.5139	18.86	4.301	0.0	0.5432;
260	137.4	0.0	21.97	31.13	22.5740	19.78	4.409	0.0	0.5580; merging;
270	137.0	0.0	23.15	31.27	22.6874	21.80	4.640	0.0	0.5880;
285	136.1	0.0	25.17	31.47	22.8520	25.57	5.030	0.0	0.6394;
300	134.8	0.0	27.88	31.68	23.0186	31.01	5.494	0.0	0.7082;
315	132.8	0.0	31.97	31.89	23.1901	39.71	6.069	0.0	0.8119;
330	129.8	0.0	38.12	32.09	23.3468	53.38	6.733	0.0	0.9682;
345	125.7	0.0	46.20	32.23	23.4636	71.84	7.379	0.0	1.1735;
360	120.3	0.0	56.99	32.34	23.5502	96.68	8.012	0.0	1.4474;
375	113.3	0.0	71.62	32.42	23.6143	130.1	8.637	0.0	1.8191;
390	103.9	0.0	92.37	32.48	23.6595	175.1	9.262	0.0	2.3463;
405	90.64	0.0	135.4	32.56	23.6747	235.7	9.975	0.0	3.4389; trap level;
420	72.26	0.0	374.7	32.64	23.6661	298.4	11.14	0.0	9.5163;
422	71.92	0.0	431.4	32.64	23.6658	299.0	11.18	0.0	10.959; begin overlap;
435	71.08	0.0	735.9	32.64	23.6656	299.5	11.30	0.0	18.691;
450	70.83	0.0	1062.7	32.64	23.6656	299.5	11.36	0.0	26.993;
465	70.73	0.0	1377.9	32.64	23.6656	299.5	11.39	0.0	34.998;
480	70.68	0.0	1682.2	32.64	23.6656	299.5	11.40	0.0	42.727;
495	70.66	0.0	1974.9	32.64	23.6656	299.5	11.42	0.0	50.163;
510	70.64	0.0	2255.1	32.64	23.6656	299.5	11.43	0.0	57.279;
525	70.63	0.0	2521.3	32.64	23.6656	299.5	11.44	0.0	64.042;
534	70.62	0.0	2673.9	32.64	23.6656	299.5	11.44	0.0	67.917; surface;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 3.4869


Lmz(m): 3.4869

forced entrain 1 0.0 21.15 67.92 0.635

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 33.0475

;

10:43:12 AM. amb fills: 4



E.3 Minimum SEOO Discharge with Maximum Brine Additions for November 2013 Density Profiles

Project "C:\Plumes20\Min-SEOO_Nov2013_Max-Brine"
memo

Model configuration items checked:

Channel width (m) 100

Start case for graphs 1

Max detailed graphs 10 (limits plots that can overflow memory)

Elevation Projection Plane (deg) 0

Shore vector (m,deg) not checked

Bacteria model : Mancini (1978) coliform model

PDS sfc. model heat transfer : Medium

Equation of State : S, T

Similarity Profile : Default profile (k=2.0, ...)

Diffuser port contraction coefficient 0.61

Light absorption coefficient 0.16

Farfield increment (m) 200

UM3 aspiration coefficient 0.1

Output file: text output tab

Output each ?? steps 15

Maximum dilution reported 10000

Text output format : Standard

Max vertical reversals : to max rise or fall

/ UM3. 8/22/2022 11:15:11 AM

Case 1; ambient file C:\Plumes20\Min-SEOO_Nov2013_Max-Brine.001.db; Diffuser table record 1

Ambient Table:

Depth	Amb-cur	Amb-dir	Amb-sal	Amb-tem	Amb-pol	Decay	Far-spd	Far-dir	Disprsn	Density
m	m/s	deg	psu	C	kg/kg	s-1	m/s	deg	m0.67/s2	sigma-T
0.0	0.0	0.0	33.52	16.11	0.0	0.0	0.0	0.0	0.0	24.60806
3.048	0.0	0.0	33.52	16.09	0.0	0.0	0.0	0.0	0.0	24.61428
6.096	0.0	0.0	33.59	16.01	0.0	0.0	0.0	0.0	0.0	24.68104
9.143	0.0	0.0	33.60	15.98	0.0	0.0	0.0	0.0	0.0	24.69766
12.19	0.0	0.0	33.56	15.97	0.0	0.0	0.0	0.0	0.0	24.67054
15.24	0.0	0.0	33.62	15.97	0.0	0.0	0.0	0.0	0.0	24.71824
18.29	0.0	0.0	33.59	15.93	0.0	0.0	0.0	0.0	0.0	24.70539
21.33	0.0	0.0	33.53	15.75	0.0	0.0	0.0	0.0	0.0	24.69856
24.38	0.0	0.0	33.53	15.43	0.0	0.0	0.0	0.0	0.0	24.77075
27.43	0.0	0.0	33.38	15.04	0.0	0.0	0.0	0.0	0.0	24.73492
30.48	0.0	0.0	33.35	14.87	0.0	0.0	0.0	0.0	0.0	24.75546
33.53	0.0	0.0	33.37	14.84	0.0	0.0	0.0	0.0	0.0	24.77081
36.57	0.0	0.0	33.37	14.84	0.0	0.0	0.0	0.0	0.0	24.77081
39.62	0.0	0.0	33.40	14.83	0.0	0.0	0.0	0.0	0.0	24.79868
42.67	0.0	0.0	33.40	14.83	0.0	0.0	0.0	0.0	0.0	24.79868

Diffuser table:

P-dia	Ver angl	H-Angle	SourceX	SourceY	Ports	MZ-dis	Isopth	P-depth	Ttl-flo	Eff-sal	Temp	Polutnt
(in)	(deg)	(deg)	(m)	(m)	()	(m)	(concent)	(ft)	(MGD)	(psu)	(C)	(ppb)
2.0000	0.0	0.0	0.0	0.0	200.00	2000.0	0.0	140.00	7.2000	1.8800	22.500	1200.0

Simulation:

Froude No: 12.76; Strat No: 6.91E-6; Spcg No: 14.05; k: 1.27E+5; eff den (sigmaT) -0.858500;
 eff vel 1.276(m/s);

Current is very small, flow regime may be transient.

Step	Depth (ft)	Amb-cur (m/s)	P-dia (in)	Eff-sal (psu)	Density (sigmaT)	Dilutn (%)	x-posn (m)	y-posn (m)	Iso dia (m)
0	140.0	1.000E-5	1.562	1.880	-0.85850	1.000	0.0	0.0	0.03968;
1	140.0	0.0	1.592	3.080	0.11749	1.039	0.0121	0.0	0.04043; bottom hit;
15	140.0	0.0	2.114	10.42	6.08045	1.362	0.117	0.0	0.0537;
30	140.0	0.0	2.839	16.33	10.8738	1.825	0.266	0.0	0.0721;
45	140.0	0.0	3.813	20.71	14.4388	2.447	0.468	0.0	0.09684;
60	140.0	0.0	5.119	23.97	17.0919	3.285	0.740	0.0	0.1300;
75	139.9	0.0	6.834	26.36	19.0374	4.390	1.096	0.0	0.1736;
90	139.9	0.0	8.417	27.71	20.1384	5.425	1.426	0.0	0.2138;
105	139.8	0.0	9.757	28.53	20.8107	6.338	1.711	0.0	0.2478;
120	139.7	0.0	10.95	29.11	21.2863	7.194	1.969	0.0	0.2781;
135	139.6	0.0	12.05	29.56	21.6541	8.035	2.213	0.0	0.3059;
150	139.5	0.0	13.08	29.93	21.9565	8.889	2.447	0.0	0.3322;
165	139.3	0.0	14.08	30.25	22.2171	9.785	2.679	0.0	0.3576;
180	139.2	0.0	15.07	30.54	22.4499	10.75	2.911	0.0	0.3827;
195	139.0	0.0	16.07	30.80	22.6642	11.83	3.147	0.0	0.4083;
210	138.7	0.0	17.13	31.04	22.8666	13.07	3.393	0.0	0.4350;
225	138.4	0.0	18.27	31.28	23.0618	14.54	3.652	0.0	0.4640;
240	138.1	0.0	19.55	31.52	23.2535	16.34	3.929	0.0	0.4967;
255	137.6	0.0	21.07	31.75	23.4445	18.65	4.230	0.0	0.5352;
263	137.3	0.0	22.02	31.87	23.5467	20.17	4.404	0.0	0.5593; merging;
270	137.0	0.0	22.87	31.98	23.6313	21.63	4.565	0.0	0.5810;
285	136.1	0.0	24.91	32.19	23.8066	25.45	4.949	0.0	0.6328;
300	134.9	0.0	27.64	32.41	23.9831	30.96	5.407	0.0	0.7020;
315	132.8	0.0	31.76	32.63	24.1645	39.81	5.977	0.0	0.8067;
330	129.8	0.0	37.88	32.83	24.3273	53.55	6.624	0.0	0.9621;
345	125.7	0.0	45.95	32.97	24.4471	72.07	7.254	0.0	1.1672;
360	120.4	0.0	56.97	33.08	24.5329	96.99	7.877	0.0	1.4470;
375	113.3	0.0	72.18	33.15	24.5941	130.5	8.506	0.0	1.8335;
390	103.8	0.0	92.98	33.21	24.6389	175.7	9.140	0.0	2.3618;
405	90.98	0.0	124.1	33.25	24.6681	236.4	9.794	0.0	3.1517;
420	73.22	0.0	165.3	33.30	24.6896	318.2	10.49	0.0	4.1995;
435	47.34	0.0	259.4	33.37	24.6952	428.2	11.32	0.0	6.5885;
438	40.60	0.0	280.9	33.38	24.6960	454.4	11.53	0.0	7.1357; trap level;
444	24.25	0.0	375.1	33.41	24.6949	511.7	12.04	0.0	9.5275; trap level;

Horiz plane projections in effluent direction: radius(m): 0.0; CL(m): 3.6707

Lmz(m): 3.6707

forced entrain 1 0.0 35.28 9.528 0.0323

Rate sec-1 0.0 dy-1 0.0 kt: 0.0 Amb Sal 33.5954

;

11:15:12 AM. amb fills: 4

Plumes 20 (UM3) Initial Dilution Solutions, San Elijo Ocean Outfall (SEOO)
November 2013, minimum discharge (7.2 mgd) with maximum brine additions

